



South Coast Air Quality Management District

21865 Copley Drive Diamond Bar CA 91765-4178
(909) 396-2000 www.aqmd.gov

January 29, 2010

Mr Gerardo Rios
Chief, Permits Office
US EPA, Region IX- Air 3
75 Hawthorne Blvd
San Francisco, CA 94105

Dear Mr Rios

Please find attached the revised version of the Universal City Studios, LLC (SIC code 7800), (ID 800202) Facility Permit. This revision was previously sent to EPA for your review on December 17, 2010. The revised Facility Permit reflects the inclusion of the following new equipment approved for Permit to Operate:

Application No	Equipment	Page
503477	Emergency ICE	106

Please review the attached Section D. Insert the enclosed sections into the Facility Permit and discard the earlier versions. Questions concerning changes to the Facility permit should be directed to Mr Roy Olivares at (909) 396-2208.

Very truly yours,

Michael D Mills

Michael D Mills
Senior Manager
General Commercial and Energy
Team Engineering and Compliance

Attachments
CERTIFIED MAIL



South Coast Air Quality Management District



21865 Copley Drive Diamond Bar CA 91765-4178
(909) 396-2000 www.aqmd.gov

January 29, 2010

Mr Joseph Bellas
Director Environmental Programs
Universal City Studios, LLC
100 Universal City Plaza
5166/2nd Floor
Universal City, CA 91608

Attention Mr Joseph Bellas
Facility ID 800202

Please find attached the revised version of your Facility Permit The revised Facility Permit reflects the inclusion of the following equipment approved for Permit to Operate

Application No	Equipment	Page
503477	Emergency ICE	106

Please review the attached Section D Insert the enclosed sections into the Facility Permit and discard the earlier versions Questions concerning changes to the Facility permit should be directed to Mr Roy Olivares at (909) 396-2208

Very truly yours,

Michael D Mills
Senior Manager
General Commercial Team
Engineering and Compliance

Attachments
CERTIFIED MAIL



South Coast Air Quality Management District

21865 Copley Drive Diamond Bar CA 91765-4178
(909) 396-2000 www.aqmd.gov

NOTICE TO INFORM YOU OF A STATE COURT LAWSUIT AND A REQUEST SUBMITTED TO U S EPA TO STOP SCAQMD FROM ISSUING PERMITS SUCH AS YOUR PERMIT

The enclosed permit is issued to your facility in part by authorization provided under California State Law, as approved under Senate Bill (SB) 827. SB 827 was sponsored by South Coast Air Quality Management District (AQMD) and authored by Senator Rod Wright in order to lift a court-ordered freeze on issuance of permits that has been in place since November of 2008. SB 827 authorizes AQMD to provide emission offset credits, free of charge, from its internal bank to offset increases in air pollution emissions from permits such as your permit. The permit moratorium was as a result of a lawsuit brought against the AQMD by the Natural Resources Defense Council, California Communities Against Toxics, Coalition for a Safe Environment, and Communities for a Better Environment.

Recently, on December 10, 2009, the above-named environmental organizations, along with Desert Communities Against Pollution, petitioned the U S Environmental Protection Agency (EPA) requesting actions to prevent AQMD from issuing this permit and other permits. More recently, several of these organizations have filed a State Court lawsuit to stop AQMD from issuing permits using offset credits from its internal bank. This notice is also to inform you that the AQMD has responded to the petition and will respond to the lawsuit by asserting that it lacks any merit, and will continue to vigorously defend your permit against such challenges. We will also keep you informed about any events that might affect the continued validity of this permit.

Please contact Mohsen Nazemi, Deputy Executive Officer of Engineering and Compliance at (909) 396-3447, if you have any questions about your permit.



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

Facility Equipment and Requirements (Section D)

This section consists of a table listing all permitted equipment at the facility, facility wide requirements, all individual Permits to Construct and Permits to Operate issued to various equipment at the facility, and Rule 219-exempt equipment subject to source-specific requirements. Each permit and Rule 219-exempt equipment will list operating conditions including periodic monitoring requirements, and applicable emission limits and requirements that the equipment is subject to. Also included is the rule origin and authority of each emission limit and permit condition.



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMITTED EQUIPMENT LIST

THE FOLLOWING IS A LIST OF ALL PERMITS TO CONSTRUCT AND PERMITS TO OPERATE AT THIS FACILITY

Application number	Permit to Operate number	Equipment description	Page number
109262	M31544	SPRAY BOOTH	5
121393	M40987	SPRAY BOOTH	7
121394	M40988	SPRAY BOOTH	9
121395	M40989	SPRAY BOOTH	11
121397	M40990	SPRAYBOOTH	13
121398	M40991	OVEN	14
381319	F45441	SPRAY BOOTH	15
496472	G3672	ICE EM FIRE PUMP-DIESEL	17
396515	F48763	ICE EM ELEC GEN-DIESEL	19
396516	F48764	ICE EM ELEC GEN-DIESEL	21
426050	F69295	ICE EM ELEC GEN-DIESEL	23
426063	F69296	ICE EM ELEC GEN-DIESEL	25
289132	D80818	ICE EM FIRE PUMP-DIESEL	27
299771	D88950	ICE EM ELEC GEN-DIESEL	28
459463	F85211	ICE EM ELEC GEN-DIESEL	30
317699	F01255	ICE EM ELEC GEN-DIESEL	32
317701	F2630	ICE EM ELEC GEN-DIESEL	34
426052	F69244	ICE EM ELEC GEN-DIESEL	36
426067	F69290	ICE EM ELEC GEN-DIESEL	38
317868	F01256	ICE EM ELEC GEN-DIESEL	40
318123	F2527	ICE EM ELEC GEN-NATURAL GAS	42
336289	F12901	STEAM CLEANER	43
338100	F12919	ICE EM ELEC GEN-DIESEL	44
426051	F69292	ICE EM ELEC GEN-DIESEL	46
347623	F19569	STEAM CLEANER	48
426061	F69297	ICE EM ELEC GEN-DIESEL	49
379304	F41128	ICE EM ELEC GEN-DIESEL	51
379305	F41129	ICE EM ELEC GEN-DIESEL	53
426062	F69294	ICE EM ELEC GEN-DIESEL	55
426064	F68897	LANDFILL GAS SYS	57
381318	F43473	ICE EM ELEC GEN-DIESEL	59
426059	F69307	ICE EM ELEC GEN-DIESEL	61
402127	F52612	NEGATIVE AIR MACHINE	69
402128	F52613	NEGATIVE AIR MACHINE	67
392662	F46186	ICE EM ELEC GEN-DIESEL	71
393684	F48207	ABRASIVE BLASTING PORTABLE	73
402105	F52607	ICE EM ELEC GEN-DIESEL	75
396217	F48611	FILM CLEANING MACHINE	78



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

396218	F48612	AIR POLLUTION CONTROL SYSTEM	78
426053	F69293	ICE EM ELEC GEN-DIESEL	80
438542	F74244	STEAM CLEANER	82
426055	F69291	ICE EM ELEC GEN-DIESEL	83
453517	F84370	PRESSURE WASHER	85
453518	F84372	PRESSURE WASHER	86
438540	F74347	PRESSURE WASHER	87
456387	F84369	PRESSURE WASHER	88
474757	F95054	PRESSURE WASHER	89
476431	F96189	PRESSURE WASHER	90
381314	F40651	FILM CLEANING MACHINE	91
480452	F97489	PRESSURE WASHER	92
480453	F97490	PRESSURE WASHER	93
481202	F97491	ICE EM ELEC GEN-DIESEL	94
480450	N24131	SERVICE STATION	96
480451	N24132	SERVICE STATION	101
503477	G7128	ICE EM ELEC GEN-DIESEL	106

NOTE EQUIPMENT LISTED ABOVE THAT HAVE NO CORRESPONDING PERMITS TO OPERATE NUMBER ARE ISSUED PERMITS TO CONSTRUCT THE ISSUANCE OR DENIAL OF THEIR PERMITS TO OPERATE IS SUBJECT TO ENGINEERING FINAL REVIEW ANY OTHER APPLICATIONS THAT ARE STILL BEING PROCESSED AND HAVE NOT BEEN ISSUED PERMITS TO CONSTRUCT OR PERMITS TO OPERATE WILL NOT BE FOUND IN THIS TITLE V PERMIT



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

FACILITY WIDE CONDITION(S)

Condition(s)

- 1 EXCEPT FOR OPEN ABRASIVE BLASTING OPERATIONS THE OPERATOR SHALL NOT DISCHARGE INTO THE ATMOSPHERE FROM ANY SINGLE SOURCE OF EMISSIONS WHATSOEVER ANY AIR CONTAMINANT FOR A PERIOD OR PERIODS AGGREGATING MORE THAN THREE MINUTES IN ANY ONE HOUR WHICH IS
 - A AS DARK OR DARKER IN SHADE AS THAT DESIGNATED NO 1 ON THE RINGLEMANN CHART AS PUBLISHED BY THE UNITED STATES BUREAU OF MINES OR
 - B OF SUCH OPACITY AS TO OBSCURE AN OBSERVER'S VIEW TO A DEGREE EQUAL TO OR GREATER THAN DOES SMOKE DESCRIBED IN SUBPARAGRAPH (A) OF THIS CONDITION [RULE 401]
- 2 THE OPERATOR SHALL NOT USE ANY DIESEL FUEL UNLESS THE FUEL IS LOW SULFUR DIESEL FOR WHICH THE SULFUR CONTENT SHALL NOT EXCEED 15 PPM BY WEIGHT AS SUPPLIED BY THE SUPPLIER
[RULE 431 2]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No M31544
A/N 109262

Equipment Description

SPRAY BOOTH BINKS, AUTOMOTIVE TYPE MODEL TA 542-T 16' 4" W X 42'-8" L X 14' 2" H WITH SIX 20" X 36" EXHAUST FILTERS SIX 42" X 36" EXHAUST FILTERS AND ONE 7 1/2 HP EXHAUST FAN

Conditions

- 1 THIS SPRAY BOOTH SHALL NOT BE OPERATED UNLESS ALL EXHAUST AIR PASSES THROUGH FILTER MEDIA
[RULE 1303 (a)-BACT]
- 2 A GAUGE SHALL BE INSTALLED TO INDICATE IN INCHES OF WATER THE STATIC PRESSURE DIFFERENTIAL ACROSS THE EXHAUST FILTERS IN OPERATION THE PRESSURE DIFFERENTIAL MUST NOT EXCEED 0.25 INCH OF WATER
[RULE 1303 (a)-BACT]
- 3 THE TOTAL QUANTITY OF COATINGS AND SOLVENTS USED IN THIS EQUIPMENT SHALL NOT EXCEED 7 GALLONS IN ANY ONE DAY
[RULE 1303 (b)(2)]

Periodic Monitoring

- 4 THE OPERATOR SHALL DETERMINE AND RECORD THE PRESSURE DROP ACROSS THE FILTER MEDIA ONCE EVERY WEEK
[RULE 3004 (a)(4)]
- 5 THE OPERATOR SHALL PERFORM A WEEKLY INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA THE OPERATOR SHALL KEEP RECORDS IN A MANNER APPROVED BY THE DISTRICT FOR THE FOLLOWING PARAMETER(S) OR ITEM(S)
 - A THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA
 - B THE DATE TIME AND RESULTS OF THE INSPECTION AND
 - C THE DATE TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION[RULE 3004 (a)(4)]

Emissions And Requirements

- 6 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS



**FACILITY PERMIT TO OPERATE
UNIVERSAL CITY STUDIOS, LLC**

VOC RULE 109
VOC RULE 1107 SEE APPENDIX B FOR EMISSIONS LIMITS
VOC RULE 1145 SEE APPENDIX B FOR EMISSIONS LIMITS
VOC RULE 1171 SEE APPENDIX B FOR EMISSIONS LIMITS
VOC RULE 1151 SEE APPENDIX B FOR EMISSIONS LIMITS
VOC RULE 1106 1 SEE APPENDIX B FOR EMISSIONS LIMITS
PM RULE 481
PM RULE 404, SEE APPENDIX B FOR EMISSIONS LIMITS



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No M40987
A/N 121393

Equipment Description

SPRAY BOOTH BINKS PUMPLESS WATERWASH TYPE, MODEL NO NPB-16-10-TLH 16-0' W X 12' 8" L X 9'-10" H WITH ONE 20 HP EXHAUST FAN

Conditions

- 1 THIS SPRAY BOOTH SHALL NOT BE OPERATED UNLESS THE WATERWASH UNIT IS PROPERLY MAINTAINED AND IN FULL OPERATION
[RULE 1303 (a)-BACT]
- 2 THE TOTAL QUANTITY OF RESINS AND CATALYST USED IN THIS EQUIPMENT SHALL NOT EXCEED 55 GALLONS IN ANY ONE DAY
[RULE 1303 (b)(2)]

Periodic Monitoring

- 3 THE OPERATOR SHALL NOT OPERATE THIS EQUIPMENT UNLESS THE WATER WASH UNIT IS PROPERLY MAINTAINED AND IN FULL OPERATION WITH THE WATER TROUGH COMPLETELY COVERING THE EXHAUST SECTION OF THE BOOTH THE OPERATOR SHALL ALSO PERFORM A WEEKLY INSPECTION OF THE WATER TROUGH INTEGRITY THE OPERATOR SHALL KEEP RECORDS IN A MANNER APPROVED BY THE DISTRICT, FOR THE FOLLOWING PARAMETER(S) OR ITEM(S)
 - A THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE WATER TROUGH
 - B THE DATE TIME AND RESULTS OF THE INSPECTION AND
 - C THE DATE TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION[RULE 3004 (a)(4)]
- 4 THE WATER LEVEL IN THE WATER TROUGH SHALL BE MAINTAINED TO NO MORE THAN EIGHT INCHES FROM THE TOP OF THE WATER TROUGH
[RULE 3004 (a)(4)]

Emissions And Requirements

- 5 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
 - VOC RULE 109
 - VOC RULE 1162 SEE APPENDIX B FOR EMISSIONS LIMITS



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive Diamond Bar CA 91765

Section D Page 8
Facility I D # 800202
Revision Rev 6
Date January 29, 2010

FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

VOC RULE 1171 SEE APPENDIX B FOR EMISSIONS LIMITS
PM RULE 481
PM RULE 404, SEE APPENDIX B FOR EMISSIONS LIMITS



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No M40988
A/N 121394

Equipment Description

SPRAY BOOTH, BINKS AUTOMOTIVE WATERWASH TYPE, 14'-0" W X 53'-0 L X 12 0 H, WITH ONE 5 HP WATER PUMP AND TWO 7 1/2 HP EXHAUST FANS

Conditions

- 1 THIS SPRAY BOOTH SHALL NOT BE OPERATED UNLESS THE WATERWASH UNIT IS PROPERLY MAINTAINED AND IN FULL OPERATION
[RULE 1303 (a) BACT]
- 2 THE TOTAL QUANTITY OF COATINGS AND SOLVENTS USED IN THIS EQUIPMENT SHALL NOT EXCEED 6 GALLONS IN ANY ONE DAY
[RULE 1303 (b)(2)]

Periodic Monitoring

- 3 THE OPERATOR SHALL NOT OPERATE THIS EQUIPMENT UNLESS THE WATER WASH UNIT IS PROPERLY MAINTAINED AND IN FULL OPERATION WITH THE WATER CURTAIN COMPLETELY COVERING THE EXHAUST SECTION OF THE BOOTH THE OPERATOR SHALL ALSO PERFORM A WEEKLY INSPECTION OF THE WATER CURTAIN INTEGRITY THE OPERATOR SHALL KEEP RECORDS IN A MANNER APPROVED BY THE DISTRICT FOR THE FOLLOWING PARAMETER(S) OR ITEM(S)
 - A THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE WATER WASH
 - B THE DATE TIME AND RESULTS OF THE INSPECTION AND
 - C THE DATE TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION[RULE 3004 (a)(4)]

Emissions And Requirements

- 4 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
 - VOC RULE 109
 - VOC RULE 1107 SEE APPENDIX B FOR EMISSIONS LIMITS
 - VOC RULE 1145, SEE APPENDIX B FOR EMISSIONS LIMITS
 - VOC RULE 1136 SEE APPENDIX B FOR EMISSIONS LIMITS
 - VOC RULE 1171 SEE APPENDIX B FOR EMISSIONS LIMITS
 - VOC RULE 1151, SEE APPENDIX B FOR EMISSIONS LIMITS
 - VOC RULE 1106 1 SEE APPENDIX B FOR EMISSIONS LIMITS



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT
21865 Copley Drive Diamond Bar CA 91765

Section D Page 10
Facility I D # 800202
Revision Rev 6
Date January 29, 2010

FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PM RULE 481
PM RULE 404 SEE APPENDIX B FOR EMISSIONS LIMITS



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No M40989
A/N 121395

Equipment Description

SPRAY BOOTH, BINKS FLOOR FILTER TYPE MODEL PFA 14 8 TLH 14 0 W X 8' 0' H X 11 2 L WITH TWO ANDREA FILTERS AND ONE 5 HP EXHAUST FAN

Conditions

- 1 THIS SPRAY BOOTH SHALL NOT BE OPERATED UNLESS ALL EXHAUST AIR PASSES THROUGH FILTER MEDIA
[RULE 1303 (a) BACT]
- 2 A GAUGE SHALL BE INSTALLED TO INDICATE, IN INCHES OF WATER, THE STATIC PRESSURE DIFFERENTIAL ACROSS THE EXHAUST FILTERS IN OPERATION THE PRESSURE DIFFERENTIAL MUST NOT EXCEED 0 25 INCH OF WATER
[RULE 1303 (a) BACT]
- 3 THE TOTAL QUANTITY OF COATINGS AND SOLVENTS USED IN THIS EQUIPMENT SHALL NOT EXCEED 6 GALLONS IN ANY ONE DAY
[RULE 1303 (b)(2)]

Periodic Monitoring

- 4 THE OPERATOR SHALL DETERMINE AND RECORD THE PRESSURE DROP ACROSS THE FILTER MEDIA ONCE EVERY WEEK
[RULE 3004 (a)(4)]
- 5 THE OPERATOR SHALL PERFORM A WEEKLY INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA THE OPERATOR SHALL KEEP RECORDS IN A MANNER APPROVED BY THE DISTRICT FOR THE FOLLOWING PARAMETER(S) OR ITEM(S)
 - A THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA
 - B THE DATE TIME AND RESULTS OF THE INSPECTION AND
 - C THE DATE TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION[RULE 3004 (a)(4)]

Emissions And Requirements

- 6 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS



**FACILITY PERMIT TO OPERATE
UNIVERSAL CITY STUDIOS, LLC**

VOC RULE 109
VOC RULE 1107 SEE APPENDIX B FOR EMISSIONS LIMITS
VOC RULE 1145, SEE APPENDIX B FOR EMISSIONS LIMITS
VOC RULE 1136, SEE APPENDIX B FOR EMISSIONS LIMITS
VOC RULE 1171, SEE APPENDIX B FOR EMISSIONS LIMITS
PM RULE 481
PM RULE 404, SEE APPENDIX B FOR EMISSIONS LIMITS



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No M40990
A/N 121397

Equipment Description

SPRAY BOOTH BINKS FLOOR WATERWASH TYPE, MODEL WE-16-10 TLH 16'-0" W X 25' 1" L X 10' 0" H
WITH ONE 10 1/2 HP WATER PUMP AND ONE 10 HP EXHAUST FAN

Conditions

- 1 THIS SPRAY BOOTH SHALL NOT BE OPERATED UNLESS THE WATERWASH UNIT IS PROPERLY MAINTAINED AND IN FULL OPERATION
[RULE 1303 (a) BACT]
- 2 THE TOTAL QUANTITY OF COATINGS AND SOLVENTS USED IN THIS EQUIPMENT SHALL NOT EXCEED 6 GALLONS IN ANY ONE DAY
[RULE 1303 (b)(2)]

Periodic Monitoring

- 3 THE OPERATOR SHALL NOT OPERATE THIS EQUIPMENT UNLESS THE WATER WASH UNIT IS PROPERLY MAINTAINED AND IN FULL OPERATION WITH THE WATER CURTAIN COMPLETELY COVERING THE EXHAUST SECTION OF THE BOOTH THE OPERATOR SHALL ALSO PERFORM A WEEKLY INSPECTION OF THE WATER CURTAIN INTEGRITY THE OPERATOR SHALL KEEP RECORDS IN A MANNER APPROVED BY THE DISTRICT FOR THE FOLLOWING PARAMETER(S) OR ITEM(S)
 - A THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE WATER WASH
 - B THE DATE TIME AND RESULTS OF THE INSPECTION, AND
 - C THE DATE TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION[RULE 3004 (a)(4)]

Emissions And Requirements

- 4 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
 - VOC RULE 109
 - VOC RULE 1107 SEE APPENDIX B FOR EMISSIONS LIMITS
 - VOC RULE 1145 SEE APPENDIX B FOR EMISSIONS LIMITS
 - VOC RULE 1136 SEE APPENDIX B FOR EMISSIONS LIMITS
 - VOC RULE 1171, SEE APPENDIX B FOR EMISSIONS LIMITS
 - PM RULE 481
 - PM RULE 404 SEE APPENDIX B FOR EMISSIONS LIMITS



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No M40991
A/N 121398

Equipment Description

OVEN, BINKS, BATCH TYPE 16-0 W X 26'-0" L X 8' 0" H 1,500 000 BTU PER HOUR, DIRECT GAS FIRED WITH ONE 15 HP CIRCULATION FAN AND ONE 1 HP EXHAUST FAN

Conditions

- 1 THIS OVEN SHALL NOT BE OPERATED AT TEMPERATURES ABOVE 250 DEGREES FAHRENHEIT

Periodic Monitoring

- 2 THE OPERATOR SHALL INSTALL AND MAINTAIN A TEMPERATURE INDICATOR TO READ DEVICE READING DEGRESS FAHRENHEIT TO ACCURATELY INDICATE THE TEMPERATURE OF THE OVEN
[RULE 3004 (a)(4)]

Emissions And Requirements

- 3 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS

CO 2000 PPMV RULE 407
SOX 500 PPMV RULE 407
PM 0 1 GR/SCF, RULE 409



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

**Permit No F45441
A/N 381319**

Equipment Description

SPRAY BOOTH BLEEKER, MODEL APL 26 AUTOMOTIVE TYPE, 14'-0" W X 26'-0" L X 9' 0" H WITH EIGHTEEN 20 X 20 EXHAUST FILTERS AND ONE 2 HP EXHAUST FAN

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 THIS SPRAY BOOTH SHALL NOT BE OPERATED UNLESS ALL EXHAUST AIR PASSES THROUGH FILTER MEDIA AT LEAST 2 INCHES THICK
[RULE 1303 (a)-BACT]
- 4 A GAUGE SHALL BE INSTALLED TO INDICATE IN INCHES OF WATER THE STATIC PRESSURE DIFFERENTIAL ACROSS THE EXHAUST FILTERS IN OPERATION THE PRESSURE DIFFERENTIAL MUST NOT EXCEED 0.25 INCH OF WATER
[RULE 1303 (a) BACT]
- 5 THIS EQUIPMENT SHALL COMPLY WITH RULES 1107 1136 1145 AND 1171
[RULE 1107 RULE 1136 RULE 1145, RULE 1171]
- 6 MATERIAL SAFETY DATA SHEETS FOR ALL COATINGS AND SOLVENT USED AT THIS FACILITY SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1303 (a) BACT]
- 7 THE TOTAL QUANTITY OF COATINGS AND SOLVENTS USED IN THIS EQUIPMENT SHALL NOT EXCEED 6 GALLONS IN ANY ONE DAY
[RULE 1303 (b)(2) OFFSETS]
- 8 THE OPERATOR SHALL COMPLY WITH RULE 109 (RECORD KEEPING FOR VOLATILE ORGANIC COMPOUND EMISSIONS)
[RULE 109]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 9 IN ADDITION TO COMPLYING WITH RULE 109 THE OPERATOR SHALL KEEP ADEQUATE RECORDS FOR THIS FACILITY TO VERIFY VOC CONTENT OF EACH COATING AS APPLIED (INCLUDING WATER AND EXEMPT COMPOUNDS) ALL RECORDS SHALL BE PREPARED IN A FORMAT WHICH IS ACCEPTABLE TO THE DISTRICT AND SHALL BE RETAINED AT THE FACILITY FOR AT LEAST 24 MONTHS, AND SHALL BE MADE AVAILABLE TO ANY DISTRICT REPRESENTATIVE UPON REQUEST
[RULE 109]

Periodic Monitoring

- 10 THE OPERATOR SHALL DETERMINE AND RECORD THE PRESSURE DROP ACROSS THE FILTER MEDIA ONCE EVERY WEEK
[RULE 3004 (a)(4)]
- 11 THE OPERATOR SHALL PERFORM A WEEKLY INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS, BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA THE OPERATOR SHALL KEEP RECORDS IN A MANNER APPROVED BY THE DISTRICT FOR THE FOLLOWING PARAMETER(S) OR ITEM(S)
- A THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA
 - B THE DATE, TIME AND RESULTS OF THE INSPECTION, AND
 - C THE DATE TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION
- [RULE 3004 (a)(4)]

Emissions And Requirements

- 12 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- | | |
|-----|---|
| VOC | RULE 109 |
| VOC | RULE 1107 SEE APPENDIX B FOR EMISSIONS LIMITS |
| VOC | RULE 1145 SEE APPENDIX B FOR EMISSIONS LIMITS |
| VOC | RULE 1136 SEE APPENDIX B FOR EMISSIONS LIMITS |
| VOC | RULE 1171 SEE APPENDIX B FOR EMISSIONS LIMITS |
| PM | RULE 481 |
| PM | RULE 404 SEE APPENDIX B FOR EMISSIONS LIMITS |



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No G3672
A/N 496472

Equipment Description

INTERNAL COMBUSTION ENGINE, CATERPILLAR DIESEL FUELED MODEL NO 3208NA/175 SERIAL NO 90N71047 8 CYLINDERS, FOUR CYCLE NATURALLY ASPIRATED 165 BHP DRIVING FIRE PUMP

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431 2 RULE AND 1470
[RULE 431 2 RULE 1470]
- 4 AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1110 2 RULE 1470]
- 5 THIS ENGINE SHALL NOT BE OPERATED MORE THAN A TOTAL OF 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 34 HOURS PER YEAR FOR TESTING AND MAINTENANCE TO COMPLY WITH THE REQUIREMENTS OF THE NATIONAL FIRE PROTECTION ASSOCIATION
[RULE 1110 2 RULE 1470]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 6 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL INCLUDE MANUAL AND AUTOMATIC OPERATION AND SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS

A EMERGENCY USE HOURS OF OPERATION

B MAINTENANCE AND TESTING HOURS

C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION EACH TIME THE ENGINE IS STATED MANUALLY THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
[RULE 1110 2 RULE 1470]

Emissions And Requirements

- 4 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS

PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS

PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F48763
A/N 396515

Equipment Description

INTERNAL COMBUSTION ENGINE CATERPILLAR, MODEL NO 3406 B TA DIESEL FUELED 6 CYLINDERS FOUR CYCLE TURBOCHARGED AND AFTERCOOLED RATED AT 519 B H P DRIVING AN EMERGENCY ELECTRICAL GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a), RULE 1110 2 RULE 1470]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a) RULE 1303 (a) BACT, RULE 1110 2 RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR
[RULE 1470]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS
- A EMERGENCY USE HOURS OF OPERATION
 - B MAINTENANCE AND TESTING HOURS
 - C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)
- IN ADDITION EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
[RULE 1304 (a), RULE 1110.2, RULE 1470]
- 8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470
[RULE 431.2, RULE 1470]
- 9 THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING
[RULE 1303 (a) BACT]

Emissions And Requirements

- 10 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- PM RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
 - PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F48764
A/N 396516

Equipment Description

INTERNAL COMBUSTION ENGINE, CUMMINS MODEL NO NTA855-G2 DIESEL FUELED, 6 CYLINDERS, FOUR CYCLE TURBOCHARGED AND AFTERCOOLED, RATED AT 465 B H P DRIVING AN EMERGENCY ELECTRICAL GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a) RULE 1110.2 RULE 14710]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a) RULE 1303 (a) BACT RULE 1110.2 RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR
[RULE 1470]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS
- A EMERGENCY USE HOURS OF OPERATION
 - B MAINTENANCE AND TESTING HOURS
 - C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)
- IN ADDITION EACH TIME THE ENGINE IS STARTED MANUALLY THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
[RULE 1304 (a) RULE 1110.2 RULE 1470]
- 8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470
[RULE 431.2 RULE 1470]
- 9 THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING
[RULE 1303 (a)-BACT]

Emissions And Requirements

- 10 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS
 - PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F69295
A/N 426050

Equipment Description

INTERNAL COMBUSTION ENGINE DETROIT DIESEL, MODEL NO 8063 7305 SERIAL NO 6VF197434, DIESEL FUELED, EMERGENCY ELECTRICAL GENERATOR DRIVER, TURBOCHARGED AFTERCOOLED 6 CYLINDERS, 370 BHP

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 A TIMER SHALL BE MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a) RULE 1303 (a) BACT RULE 1110 2 RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR
[RULE 1470]
- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

A EMERGENCY USE HOURS OF OPERATION

B MAINTENANCE AND TESTING HOURS

C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION EACH TIME THE ENGINE IS STARTED MANUALLY THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR

[RULE 1304 (a) RULE 1110.2 RULE 1470]

8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470
[RULE 431.2 RULE 1470]

9 THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE RETARDED A MINIMUM OF 4 DEGREES RELATIVE TO STANDARD TIMING
[RULE 1303 (a)-BACT]

Emissions And Requirements

10 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS

PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS

PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F69296
A/N 426063

Equipment Description

INTERNAL COMBUSTION ENGINE, CATERPILLAR, 8 CYLINDERS, TURBOCHARGED AFTERCOOLED, MODEL NO 3508 DITA (825 KW) 1106 BHP DIESEL FUELED DRIVING AN EMERGENCY ELECTRICAL GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 A TIMER SHALL BE MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a) RULE 1110 2, RULE 1470]
- 5 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 6 THE OPERATION OF THE ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 7 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR
[RULE 1470]
- 8 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

A EMERGENCY USE HOURS OF OPERATION

B MAINTENANCE AND TESTING HOURS

C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
[RULE 1304 (a) RULE 1110.2 RULE 1470]

- 9 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF
RULES 431.2 AND 1470
[RULE 431.2 RULE 1470]

Emissions And Requirements

- 10 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS
- PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No D80818
A/N 289132

Equipment Description

INTERNAL COMBUSTION ENGINE, CATERPILLAR, MODEL NO 3306BDITA, 6 CYLINDERS, FOUR CYCLE
LEAN BURN TURBOCHARGED, AFTERCOOLED, DIESEL FUELED 287 BHP, DRIVING AN EMERGENCY,
FIRE WATER PUMP

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA
AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS
ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING
CONDITION AT ALL TIMES
[RULE 204]
- 3 A TIMER SHALL BE MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a)]
- 4 THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES
RETARDED RELATIVE TO STANDARD TIMING
[RULE 1304 (a) RULE 1110 2]
- 5 THE OPERATING TIME OF THIS ENGINE SHALL NOT EXCEED 200 HOURS IN ANY ONE YEAR
[RULE 1304 (a)]
- 6 THE OPERATING TIME OF THIS ENGINE DURING TESTING AND MAINTENANCE SHALL NOT
EXCEED 34 HOURS IN ANY ONE YEAR
[RULE 1470]
- 7 AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION THE ELAPSED TIME IN
HOURS AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A
MINIMUM OF TWO YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1304 (a)]

Emissions And Requirements

- 8 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES
AND REGULATIONS
PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS
PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No D88950
A/N 299771

Equipment Description

INTERNAL COMBUSTION ENGINE CATERPILLAR 6 CYLINDERS TURBOCHARGED AFTERCOOLED
MODEL NO 3306 ATAAC 377 BHP DIESEL-FUELED DRIVING AN EMERGENCY ELECTRICAL
GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 A TIMER SHALL BE MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a) RULE 1303 (a)-BACT RULE 1110 2 RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR
[RULE 1470]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS
- A EMERGENCY USE HOURS OF OPERATION
 - B MAINTENANCE AND TESTING HOURS
 - C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)
- IN ADDITION EACH TIME THE ENGINE IS STARTED MANUALLY THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
[RULE 1304 (a) RULE 1110 2, RULE 1470]
- 8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431 2 AND 1470
[RULE 431 2 RULE 1470]

Emissions And Requirements

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F85211
A/N 459463

Equipment Description

INTERNAL COMBUSTION ENGINE CUMMINS 4 CYLINDERS TURBOCHARGED, MODEL NO 4BT3 9G2
102 BHP, DIESEL FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 A TIMER SHALL BE MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a), RULE 1303 (a) BACT RULE 1110 2 RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR
[RULE 1470]
- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS
 - A EMERGENCY USE HOURS OF OPERATION



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

B MAINTENANCE AND TESTING HOURS

C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
[RULE 1304 (a), RULE 1110 2, RULE 1470]

- 8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF
RULES 431 2 AND 1470
[RULE 431 2 RULE 1470]

Emissions And Requirements

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS
- PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

**Permit No F01255
A/N 317699**

Equipment Description

INTERNAL COMBUSTION ENGINE JOHN DEERE 6 CYLINDERS, TURBOCHARGED MODEL NO 6059T, 150 BHP DIESEL FUELED, DRIVING AN EMERGENCY ELECTRICAL GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 A TIMER SHALL BE MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a) RULE 1110.2 RULE 1470]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a) RULE 1110.2 RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR
[RULE 1470]
- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS
 - A EMERGENCY USE HOURS OF OPERATION



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

B MAINTENANCE AND TESTING HOURS

C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION EACH TIME THE ENGINE IS STARTED MANUALLY THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
[RULE 1304 (a) RULE 1110.2 RULE 1470]

8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470
[RULE 431.2 RULE 1470]

9 THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 3 DEGREES RETARDED RELATIVE TO PRODUCTION TIMING AS ESTABLISHED BY JOHN DEERE IN ANNOUNCEMENT FOR GENERATOR DRIVE ENGINE TIMING RETARD INSTRUCTION SCAQMD CERTIFIED EQUIPMENT PERMIT APPLICATION NO. 270733
[RULE 1303 (a)-BACT]

Emissions And Requirements

10 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS
PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F2630
A/N 317701

Equipment Description

INTERNAL COMBUSTION ENGINE INTERNATIONAL HARVESTER, MODEL NO UD-407, SERIAL NO 407DU2U058822 DIESEL-FUELED 6 CYLINDERS NATURALLY ASPIRATED 91 BHP, DRIVING AN EMERGENCY ELECTRICAL GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 A TIMER SHALL BE MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a), RULE 1110.2 RULE 1401]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a) RULE 1110.2 RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR
[RULE 1470]
- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

A EMERGENCY USE HOURS OF OPERATION

B MAINTENANCE AND TESTING HOURS

C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
[RULE 1304 (a), RULE 1110 2 RULE 1470]

8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF
RULES 431 2 AND 1470
[RULE 431 2 RULE 1470]

9 THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES
RETARDED RELATIVE TO STANDARD TIMING
[RULE 1304 (a), RULE 1110 2]

Emissions And Requirements

10 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES
AND REGULATIONS

PM RULE 404, SEE APPENDIX B FOR EMISSION LIMITS

PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

**Permit No F69244
A/N 426052**

Equipment Description

INTERNAL COMBUSTION ENGINE PERKINS MODEL YB70294 SERIAL NO U586727Y DIESEL FUEL 6 CYLINDERS TURBOCHARGED AND AFTERCOOLED RATED AT 168 B H P, DRIVING AN EMERGENCY STAND-BY GENERATOR (LOCATED AT BUILDING SC-79)

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 A TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a), RULE 1110.2 RULE 1470]
- 4 THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING
[RULE 1303 (a) BACT]
- 5 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a) RULE 1110.2 RULE 1470]
- 6 THE OPERATION OF THE ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 7 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

[RULE 1470]

- 8 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS
- A EMERGENCY USE HOURS OF OPERATION
 - B MAINTENANCE AND TESTING HOURS
 - C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)
- IN ADDITION EACH TIME THE ENGINE IS STARTED MANUALLY THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
- [RULE 1304 (a) RULE 1110 2 RULE 1470]
- 9 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431 2 AND 1470
- [RULE 431 2 RULE 1470]

Emissions And Requirements

- 10 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS
 - PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F69290
A/N 426067

Equipment Description

INTERNAL COMBUSTION ENGINE PERKINS MODEL LJ70296 SERIAL NO U593523X DIESEL FUEL, 4 CYLINDERS TURBOCHARGED RATED AT 94 B H P, DRIVING AN EMERGENCY STAND-BY GENERATOR (LOCATED AT BUILDING 79)

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 A TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a), RULE 1110 2 RULE 1470]
- 4 THE FUEL INJECTION TIMING OF THIS ENGINE SHALL BE SET AND MAINTAINED AT 4 DEGREES RETARDED RELATIVE TO STANDARD TIMING
[RULE 1303 (a) BACT]
- 5 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 6 THE OPERATION OF THE ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 7 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR
[RULE 1470]

- 8 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS
- A EMERGENCY USE HOURS OF OPERATION
 - B MAINTENANCE AND TESTING HOURS
 - C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)
- IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 9 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431 2 AND 1470
[RULE 431 2 RULE 1470]

Emissions And Requirements

- 10 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- PM RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
 - PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F01256
A/N 317868

Equipment Description

INTERNAL COMBUSTION ENGINE CUMMINS 6 CYLINDERS TURBOCHARGED AFTERCOOLED MODEL NO 6BT5 9-G1 135 BHP DIESEL-FUELED DRIVING AN EMERGENCY ELECTRICAL GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 A TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR
[RULE 1470]
- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS
 - A EMERGENCY USE HOURS OF OPERATION



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

B MAINTENANCE AND TESTING HOURS

C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
[RULE 1304 (a) RULE 1110 2 RULE 1470]

- 8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF
RULES 431 2 AND 1470
[RULE 431 2 RULE 1470]

Emissions And Requirements

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS
- PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

**Permit No F2527
A/N 318123**

Equipment Description

INTERNAL COMBUSTION ENGINE FORD NATURAL GAS FUELED, EMERGENCY ELECTRICAL
GENERATION MODEL NO 3002719 HT 6 CYLINDERS NATURALLY ASPIRATED 59 BHP

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 A TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a), RULE 1110 2]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR
[RULE 1304 (a), RULE 1110 2]
- 5 AN ENGINE OPERATING LOG LISTING THE DATE OF OPERATION THE ELAPSED TIME IN HOURS AND THE REASON FOR OPERATION SHALL BE KEPT AND MAINTAINED ON FILE FOR A MINIMUM OF TWO YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1304 (a) RULE 1110 2]

Emissions And Requirements

- 6 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F12901
A/N 336289

Equipment Description

HIGH PRESSURE STEAM CLEANER, ALLADIN MODEL NO 1435 DIESEL FIRED 476 000 BTU PER HOUR
RATING (LOCATED AT TRANSPORTATION DEPARTMENT GARAGE 152 B)

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA
AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS
ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING
CONDITION AT ALL TIMES
[RULE 204]

Emissions And Requirements

- 3 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES
AND REGULATIONS
CO 2000 PPMV RULE 407
SOX 500 PPMV RULE 407
PM 0.1 GR/SCF RULE 409



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

**Permit No F12919
A/N 338100**

Equipment Description

INTERNAL COMBUSTION ENGINE CATERPILLAR, 8 CYLINDERS, TURBOCHARGED MODEL NO 3208T (150 KW) SERIAL NO 5YF01832 240 BHP DIESEL FUELED DRIVING AN EMERGENCY ELECTRICAL GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 A TIMER SHALL BE INSTALLED SO AS TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a) RULE 1110 2, RULE 1470]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR
[RULE 1470]
- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

A EMERGENCY USE HOURS OF OPERATION
B MAINTENANCE AND TESTING HOURS
C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)
IN ADDITION EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
[RULE 1304 (a), RULE 1110.2 RULE 1470]

- 8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470
[RULE 431.2, RULE 1470]

Emissions And Requirements

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- PM RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F69292
A/N 426051

Equipment Description

INTERNAL COMBUSTION ENGINE WAUKESHA MODEL NO VLRDBS L579DS SERIAL NO 1124493
DIESEL FUELED 12 CYLINDERS, TURBOCHARGED 1262 BHP DRIVING AN EMERGENCY ELECTRICAL
GENERATOR (LOCATED BEHIND BUILDING 218)

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 A NON-RESETTABLE TIMER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1110 2 RULE 1110 2]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1110 2 RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR
[RULE 1470]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS
- A EMERGENCY USE HOURS OF OPERATION
 - B MAINTENANCE AND TESTING HOURS
 - C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)
- IN ADDITION EACH TIME THE ENGINE IS STARTED MANUALLY THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431 2 AND 1470
[RULE 431 2, RULE 1470]

Emissions And Requirements

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- PM RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
 - PM RULE 1470



**FACILITY PERMIT TO OPERATE
UNIVERSAL CITY STUDIOS, LLC**

PERMIT TO OPERATE

**Permit No F19569
A/N 347623**

Equipment Description

STEAM CLEANER (TOURS AREA) ALL AMERICAN MODEL NO 3000G DIESEL FIRED WITH ONE
BURNER, 0 42 MMBTU PER HOUR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA
AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS
ISSUED UNLESS OTHERWISE NOTED BELOW
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING
CONDITION AT ALL TIMES
[RULE 204]

Emissions And Requirements

- 3 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES
AND REGULATIONS
CO 2000 PPMV RULE 407
SOX 500 PPMV RULE 407
PM 0 1 GR/SCF RULE 409



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

**Permit No F69297
A/N 426061**

Equipment Description

INTERNAL COMBUSTION ENGINE, VOLVO PENTA, MODEL TAD1631GE, SERIAL NO 2160035892WA522269-1199, DIESEL FUEL SIX CYLINDERS TURBOCHARGED AND AFTERCOOLED RATED AT 748 BHP DRIVING AN EMERGENCY STAND BY GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a) RULE 1110.2 RULE 1470]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 30 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a) RULE 1110.2 RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 30 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR
[RULE 1470]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS
- A EMERGENCY USE HOURS OF OPERATION
 - B MAINTENANCE AND TESTING HOURS
 - C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)
- IN ADDITION EACH TIME THE ENGINE IS STARTED MANUALLY THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
[RULE 1304 (a), RULE 1110 2, RULE 1470]
- 8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431 2 AND 1470
[RULE 431 2 RULE 1470]

Emissions And Requirements

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS
 - PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F41128
A/N 379304

Equipment Description

INTERNAL COMBUSTION ENGINE, JOHN DEERE MODEL 4039D SERIAL NO CD4039D191094 DIESEL FUEL 4 CYLINDERS, LEAN BURN, FOUR CYCLE RATED AT 66 BHP DRIVING AN EMERGENCY STAND BY GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a), RULE 1110 2 RULE 1470]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a), RULE 1110 2 RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR
[RULE 1470]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS
- A EMERGENCY USE HOURS OF OPERATION
 - B MAINTENANCE AND TESTING HOURS
 - C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)
- IN ADDITION EACH TIME THE ENGINE IS STARTED MANUALLY THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
[RULE 1304 (a) RULE 1110 2, RULE 1470]
- 8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431 2 AND 1470
[RULE 431 2, RULE 1470]

Emissions And Requirements

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS
 - PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

**Permit No F41129
A/N 379305**

Equipment Description

INTERNAL COMBUSTION ENGINE JOHN DEERE MODEL 4039D SERIAL NO CD4039D191090, DIESEL FUEL 4 CYLINDERS LEAN BURN FOUR CYCLE RATED AT 66 BHP DRIVING AN EMERGENCY STAND-BY GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a) RULE 1110.2 RULE 1470]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a) RULE 1110.2 RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR
[RULE 1470]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS
- A EMERGENCY USE HOURS OF OPERATION
 - B MAINTENANCE AND TESTING HOURS
 - C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)
- IN ADDITION EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
[RULE 1304 (a) RULE 1110 2, RULE 1470]
- 8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431 2 AND 1470
[RULE 431 2 RULE 1470]

Emissions And Requirements

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS
 - PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

**Permit No F69294
A/N 426062**

Equipment Description

INTERNAL COMBUSTION ENGINE, JOHN DEERE, MODEL 4039D SERIAL NO TO4039D351268 DIESEL FUEL 4 CYLINDERS LEAN BURN FOUR CYCLE RATED AT 66 BHP, DRIVING AN EMERGENCY STAND-BY GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 04]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

[RULE 1470]

- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS
- A EMERGENCY USE HOURS OF OPERATION
 - B MAINTENANCE AND TESTING HOURS
 - C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)
- IN ADDITION EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
- [RULE 1304 (a) RULE 1110.2 RULE 1470]
- 8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470
- [RULE 431.2 RULE 1470]

Emissions And Requirements

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS
 - PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F68897
A/N 426064

Equipment Description

LANDFILL GAS COLLECTION AND CONTROL SYSTEM CONSISTING OF

- 1 TEN OR LESS GAS COLLECTION WELLS VERTICAL 0-4 DIAMETER EACH (TRAM MAINTENANCE BUILDING)
- 2 HORIZONTAL SUBSLAB LANDFILL GAS VENT PIPING (TRAM BOARDING BUILDING)
- 3 MOISTURE SEPARATOR CAMERON ENVIRONMENTAL 55 GALLON WITH HIGH LEVEL SHUTDOWN
- 4 BLOWER HAUCK MODEL TBA 20 5 DIRECT DRIVE SERIAL NO 845768, 5 HP
- 5 FOUR (4) ACTIVATED CARBON CANISTERS (A1 THROUGH A4) WESTATES CARBON INC MODEL VSC 1200
- 6 EXHAUST STACK 0' 4" DIA X 12 0 H VENTING LFG COLLECTION AND CONTROL SYSTEM

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 THE LANDFILL GAS COLLECTED BY THE SYSTEM SHALL BE DIRECTED THROUGH AT LEAST TWO CARBON CANISTERS CONNECTED IN SERIES PRIOR TO BEING RELEASED TO THE ATMOSPHERE
[RULE 1150 1 RULE 1303 (a)(1)-BACT]
- 4 TOTAL AMOUNT OF LANDFILL GAS COLLECTED AND VENTED FROM THE VERTICAL GAS WELLS AND A NEW TRAM BOARDING BUILDING TO THE CARBON CANISTERS SYSTEM SHALL NOT EXCEED 200 SCFM
[RULE 1150 1]
- 5 A FLOW METER AND RECORDER SHALL BE INSTALLED AND MAINTAINED IN OPERATION TO MEASURE AND RECORD THE TOTAL LANDFILL VENT GAS FLOW RATE



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

[RULE 1150 1]

- 6 AN ACTIVATED CARBON CANISTER (PRIOR TO FINAL CANISTER) SHALL BE REMOVED AND REPLACED WITH A NEW ONE WHENEVER THE REDUCTION IN VOC (ADSORPTION) ACROSS THAT CANISTER IS LESS THAN 90% UNLESS THE VOC OUTLET CONCENTRATION IS LESS THAN 18 PPMV, DRY BASIS AS HEXANE AT 3% OXYGEN
[RULE 1150 1 RULE 1303 (a)(1) BACT]
- 7 VOLATILE ORGANIC COMPOUND (VOC) CONCENTRATIONS AT THE INLET MIDPOINT AND OUTLET OF THE CARBON ADSORBER SHALL BE MONITORED USING A PHOTO IONIZATION DETECTOR (PID) OR ANY APPROVED ORGANIC VAPOR ANALYZER ON A MONTHLY BASIS AND RESULTS SHALL BE RECORDED CONCURRENT WITH THE OUTLET VOC MEASUREMENT THE 0% SHALL BE MEASURED AND RECORDED
[RULE 1150 1 RULE 1303 (a)(1) BACT]
- 8 VOC CONCENTRATIONS MEASURED UNDER CONDITION NO 7 AT THE OUTLET OF THE CARBON ADSORBER SHALL NOT EXCEED 20 PPMV AS HEXANE CORRECTED TO 3% OXYGEN OR THE TOTAL VOC REMOVAL SHALL BE AT LEAST 98% BY WEIGHT
[RULE 1150 1]
- 9 RECORDS SHALL BE KEPT AND MAINTAINED FOR AT LEAST TWO YEARS AND SHALL BE AVAILABLE TO AQMD PERSONNEL UPON REQUEST
[RULE 1150 1]

Emissions And Requirements

- 10 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
GASEOUS EMISSIONS RULE 1150 1
VOC 20 PPMV RULE 1150 1



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F43473
A/N 381318

Equipment Description

INTERNAL COMBUSTION ENGINE CATERPILLAR, MODEL 3056T (100 KW) DIESEL FUEL 6 CYLINDERS
TURBOCHARGED, RATED AT 166 BHP, DRIVING AN EMERGENCY STAND BY GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 04]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR
[RULE 1470]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS
- A EMERGENCY USE HOURS OF OPERATION
 - B MAINTENANCE AND TESTING HOURS
 - C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)
- IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
[RULE 1304 (a) RULE 1110.2, RULE 1470]
- 8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470
[RULE 431.2 RULE 1470]

Emissions And Requirements

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS
 - PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F69307
A/N 426059

Equipment Description

INTERNAL COMBUSTION ENGINE, CATERPILLAR, MODEL 3054, SERIAL NO 4ZK04100, DIESEL FUEL 6 CYLINDERS LEAN BURN FOUR CYCLE TURBOCHARGED, RATED AT 128 BHP DRIVING AN EMERGENCY STAND BY GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 04]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

[RULE 1470]

- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS
 - A EMERGENCY USE HOURS OF OPERATION
 - B MAINTENANCE AND TESTING HOURS
 - C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)IN ADDITION EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
[RULE 1304 (a), RULE 1110 2, RULE 1470]
- 8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431 2 AND 1470
[RULE 431 2, RULE 1470]
- 9 THE ENGINE TIMING SHALL BE RETARDED 4 DEGREES RELATIVE TO STANDARD ENGINE TIMING
[RULE 1303 (a) BACT]

Emissions And Requirements

- 10 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
 - PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS
 - PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F52612
A/N 402127

Equipment Description

ASBESTOS NEGATIVE AIR MACHINE WITH HEPA FILTER C R S I MODEL H1990 C/ABATEMENT
TECHNOLOGIES CFM RATE 2 SPEED/650/1650

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS FILING IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 FOR EACH COMMERCIAL ABATEMENT PROJECT THE NEGATIVE AIR MACHINE(S) EXHAUST SHALL BE LOCATED A MINIMUM OF 3 METERS (10 FEET) FROM THE NEAREST RECEPTOR (ANY LOCATION WHERE THE PUBLIC CAN BE EXPOSED TO ASBESTOS FIBER EMISSIONS) AND SHALL BE LOCATED AT LEAST 10 FEET ABOVE THE GROUND
[RULE 1403]
- 4 FOR EACH COMMERCIAL ABATEMENT PROJECT LOCATED MORE THAN 3 METERS (10 FEET) BUT LESS THAN 30 METERS (98 FEET) FROM ANY RESIDENTIAL ZONING THE NEGATIVE AIR MACHINE(S) SHALL NOT EXHAUST MORE THAN A COMBINED TOTAL OF 4 8 MILLION CUBIC FEET OF AIR (THE TOTAL RATED AIR FLOW OF ALL MACHINE(S) IN CUBIC FEET PER MINUTE MULTIPLIED BY THE TOTAL NUMBER OF WORKING HOURS INVOLVING ASBESTOS REMOVAL)
[RULE 1403]
- 5 FOR EACH COMMERCIAL ABATEMENT PROJECT LOCATED GREATER THAN OR EQUAL TO 30 METERS (98 FEET) FROM ANY RESIDENTIAL ZONING, THE NEGATIVE AIR MACHINE(S) SHALL NOT EXHAUST AIR IN WHICH THE COMBINED TOTAL AIR VOLUME (THE TOTAL RATED AIR FLOW OF ALL MACHINE(S) IN CUBIC FEET PER MINUTE MULTIPLIED BY THE TOTAL NUMBER OF WORKING HOURS INVOLVING ASBESTOS REMOVAL) WILL EXCEED THE AMOUNT SPECIFIED ON TABLE 1
[RULE 1403]

TABLE 1



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

DISTANCE (METERS) TO RESIDENTIAL	DISTANCE (FEET) TO RESIDENTIAL	AIR VOLUME (MILLION CUBIC FEET)
30 to < 35	98 to < 115	7 7
35 to < 40	115 to < 131	9 9
40 to < 45	131 to < 148	13 8
45 to < 50	148 to < 164	18 8
50 to < 55	164 to < 180	24 1
55 to < 60	180 to < 197	32 1
60 to < 65	197 to < 213	40 8
65 to < 70	213 to < 230	51 0
70 to < 75	230 to < 246	62 8
75 to < 80	246 to < 262	76 5
80 to < 85	262 to < 279	92 2
85 to < 90	279 to < 295	110 0
90 to < 95	295 to < 312	130 0
95 to < 100	312 to < 328	153 0
100 to < 105	328 to < 344	179 0
105 to < 110	344 to < 361	217 0
110 to < 115	361 to < 377	250 0
115 to < 120	377 to < 394	286 0
120 to < 125	394 to < 410	325 0
125 to < 130	410 to < 427	368 0
130 to < 135	427 to < 443	415 0
135 to < 140	443 to < 459	465 0
140 and greater	459 and greater	520 0

- 6 FOR EACH ABATEMENT PROJECT THE EXHAUST OF EACH NEGATIVE AIR MACHINE SHALL BE ANALYZED BY THE PHASE CONTRAST MICROSCOPY (PCM) METHOD DURING THE FIRST DAY OF ACTUAL ASBESTOS REMOVAL AND AFTER EACH HEPA FILTER REPLACEMENT IF THIS NEGATIVE AIR MACHINE IS ADDED OR REPLACED DURING A SPECIFIC PROJECT THE EXHAUST OF THIS ADDITION OR REPLACEMENT SHALL BE ANALYZED BY THE PCM METHOD DURING THE FIRST DAY OF ITS USE DURING ACTUAL ASBESTOS REMOVAL EXHAUST SAMPLES TO BE ANALYZED SHALL ONLY BE TAKEN DURING ACTUAL ASBESTOS REMOVAL DURING EACH LONG TERM ABATEMENT PROJECT (GREATER THAN 15 CALENDAR DAYS) THE EXHAUST OF EACH NEGATIVE AIR MACHINE SHALL BE ANALYZED AT LEAST EVERY 15 CALENDAR DAYS
[RULE 1403]
- 7 THE EXHAUST CONCENTRATION OF ASBESTOS FROM THE NEGATIVE AIR MACHINE SHALL NOT EXCEED 0.01 FIBER PER CUBIC CENTIMETER
[RULE 1403]
- 8 THE NEGATIVE AIR MACHINE SHALL BE TESTED FOR LEAKAGE AFTER EACH HEPA FILTER CHANGE AND PRIOR TO COMMENCEMENT OF ANY ABATEMENT PROJECT
[RULE 1403]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 9 A PRESSURE GAUGE SHALL BE MAINTAINED TO INDICATE, IN INCHES OF WATER COLUMN, THE PRESSURE DIFFERENTIAL ACROSS THE HEPA FILTER THE PRESSURE DIFFERENTIAL ACROSS THE FILTER SHALL BE RECORDED AT THE BEGINNING OF EACH DAY OF USE AND IMMEDIATELY AFTER ANY FILTER CHANGE THE PRESSURE DIFFERENTIAL SHALL BE CHECKED PERIODICALLY AND THE PRESSURE DIFFERENTIAL SHALL NOT BE LESS THAN THE INITIAL READING (READING AT THE BEGINNING OF EACH DAY OF USE OR READING AFTER ANY FILTER CHANGE) IN THE EVENT THAT THE PRESSURE DIFFERENTIAL IS LESS THAN THE INITIAL READING THE NEGATIVE AIR MACHINE SHALL BE TURNED OFF AND SHALL BE CHECKED FOR LEAKAGE AND RUPTURE OF THE HEPA FILTER
[RULE 1403]
- 10 A MECHANICAL GAUGE SHALL BE INSTALLED SO AS TO INDICATE IN INCHES OF WATER COLUMN THE PRESSURE DIFFERENTIAL BETWEEN THE CONTAINMENT AND THE OUTSIDE THE MECHANICAL GAUGE SHALL BE LOCATED IN A MANNER THAT WILL ALLOW AN OBSERVER TO EASILY MONITOR THE DIFFERENTIAL PRESSURE FROM OUTSIDE OF THE CONTAINMENT
[RULE 1403]
- 11 THE MINIMUM PRESSURE DIFFERENTIAL BETWEEN THE CONTAINMENT AND THE OUTSIDE SHALL BE 0.02 INCH OF WATER GAUGE TO PREVENT ASBESTOS FIBERS FROM ESCAPING THE CONTAINMENT BARRIERS AND TO ENSURE THAT THE NEGATIVE AIR MACHINE AIRFLOW IS ADEQUATE
[RULE 1403]
- 12 THE OPERATOR SHALL KEEP ADEQUATE RECORDS FOR THIS NEGATIVE AIR MACHINE TO VERIFY
- 1) THE NUMBER OF WORKING HOURS PER DAY INVOLVING ASBESTOS REMOVAL AND
 - 2) THE EXHAUST CONCENTRATION INCLUDING THE TIME AND DATE OF EACH SAMPLING AND
 - 3) THE PRESSURE GAUGE READING AT THE BEGINNING OF EACH DAY OF USE AND AFTER EACH CHANGE OF HEPA FILTER INCLUDING THE TIME AND DATE OF THE READING AND
 - 4) THE DATE AND TIME OF EACH HEPA FILTER REPLACEMENT AND
 - 5) THE DATE AND TIME OF EACH MACHINE ADDITION/REPLACEMENT
- SUCH RECORDS SHALL BE
- 1 RETAINED FOR A PERIOD OF TWO YEARS AND
 - 2 MADE AVAILABLE UPON REQUEST BY THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE
- [RULE 1403]
- 13 THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE SHALL BE NOTIFIED AND A WRITTEN APPROVAL SHALL BE OBTAINED PRIOR TO COMMENCEMENT OF ANY ABATEMENT PROJECT



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 1) THE VOLUME OF WHICH WILL EXCEED THE TOTAL MACHINE(S) EXHAUST VOLUME
SPECIFIED IN CONDITIONS 4 OR 5 OR
- 2) LOCATED WITHIN 1,000 FEET FROM THE OUTER BOUNDARY OF A SCHOOL
[RULE 1403]

Emissions And Requirements

- 14 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES
AND REGULATIONS

ASBESTOS RULE 1403



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F52613
A/N 402128

Equipment Description

ASBESTOS NEGATIVE AIR MACHINE WITH HEPA FILTER C R S I MODEL H1990 C/ABATEMENT
TECHNOLOGIES CFM RATE 2 SPEED/650/1650

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS FILING IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 FOR EACH COMMERCIAL ABATEMENT PROJECT THE NEGATIVE AIR MACHINE(S) EXHAUST SHALL BE LOCATED A MINIMUM OF 3 METERS (10 FEET) FROM THE NEAREST RECEPTOR (ANY LOCATION WHERE THE PUBLIC CAN BE EXPOSED TO ASBESTOS FIBER EMISSIONS) AND SHALL BE LOCATED AT LEAST 10 FEET ABOVE THE GROUND
[RULE 1403]
- 4 FOR EACH COMMERCIAL ABATEMENT PROJECT LOCATED MORE THAN 3 METERS (10 FEET) BUT LESS THAN 30 METERS (98 FEET) FROM ANY RESIDENTIAL ZONING THE NEGATIVE AIR MACHINE(S) SHALL NOT EXHAUST MORE THAN A COMBINED TOTAL OF 4 8 MILLION CUBIC FEET OF AIR (THE TOTAL RATED AIR FLOW OF ALL MACHINE(S) IN CUBIC FEET PER MINUTE MULTIPLIED BY THE TOTAL NUMBER OF WORKING HOURS INVOLVING ASBESTOS REMOVAL)
[RULE 1403]
- 5 FOR EACH COMMERCIAL ABATEMENT PROJECT LOCATED GREATER THAN OR EQUAL TO 30 METERS (98 FEET) FROM ANY RESIDENTIAL ZONING THE NEGATIVE AIR MACHINE(S) SHALL NOT EXHAUST AIR IN WHICH THE COMBINED TOTAL AIR VOLUME (THE TOTAL RATED AIR FLOW OF ALL MACHINE(S) IN CUBIC FEET PER MINUTE MULTIPLIED BY THE TOTAL NUMBER OF WORKING HOURS INVOLVING ASBESTOS REMOVAL) WILL EXCEED THE AMOUNT SPECIFIED ON TABLE 1
[RULE 1403]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

TABLE 1

DISTANCE (METERS) TO RESIDENTIAL	DISTANCE (FEET) TO RESIDENTIAL	AIR VOLUME (MILLION CUBIC FEET)
30 to < 35	98 to < 115	7 7
35 to < 40	115 to < 131	9 9
40 to < 45	131 to < 148	13 8
45 to < 50	148 to < 164	18 8
50 to < 55	164 to < 180	24 1
55 to < 60	180 to < 197	32 1
60 to < 65	197 to < 213	40 8
65 to < 70	213 to < 230	51 0
70 to < 75	230 to < 246	62 8
75 to < 80	246 to < 262	76 5
80 to < 85	262 to < 279	92 2
85 to < 90	279 to < 295	110 0
90 to < 95	295 to < 312	130 0
95 to < 100	312 to < 328	153 0
100 to < 105	328 to < 344	179 0
105 to < 110	344 to < 361	217 0
110 to < 115	361 to < 377	250 0
115 to < 120	377 to < 394	286 0
120 to < 125	394 to < 410	325 0
125 to < 130	410 to < 427	368 0
130 to < 135	427 to < 443	415 0
135 to < 140	443 to < 459	465 0
140 and greater	459 and greater	520 0

- 6 FOR EACH ABATEMENT PROJECT THE EXHAUST OF EACH NEGATIVE AIR MACHINE SHALL BE ANALYZED BY THE PHASE CONTRAST MICROSCOPY (PCM) METHOD DURING THE FIRST DAY OF ACTUAL ASBESTOS REMOVAL AND AFTER EACH HEPA FILTER REPLACEMENT IF THIS NEGATIVE AIR MACHINE IS ADDED OR REPLACED DURING A SPECIFIC PROJECT THE EXHAUST OF THIS ADDITION OR REPLACEMENT SHALL BE ANALYZED BY THE PCM METHOD DURING THE FIRST DAY OF ITS USE DURING ACTUAL ASBESTOS REMOVAL EXHAUST SAMPLES TO BE ANALYZED SHALL ONLY BE TAKEN DURING ACTUAL ASBESTOS REMOVAL DURING EACH LONG TERM ABATEMENT PROJECT (GREATER THAN 15 CALENDAR DAYS) THE EXHAUST OF EACH NEGATIVE AIR MACHINE SHALL BE ANALYZED AT LEAST EVERY 15 CALENDAR DAYS
[RULE 1403]
- 7 THE EXHAUST CONCENTRATION OF ASBESTOS FROM THE NEGATIVE AIR MACHINE SHALL NOT EXCEED 0.01 FIBER PER CUBIC CENTIMETER
[RULE 1403]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 8 THE NEGATIVE AIR MACHINE SHALL BE TESTED FOR LEAKAGE AFTER EACH HEPA FILTER CHANGE AND PRIOR TO COMMENCEMENT OF ANY ABATEMENT PROJECT
[RULE 1403]
- 9 A PRESSURE GAUGE SHALL BE MAINTAINED TO INDICATE IN INCHES OF WATER COLUMN, THE PRESSURE DIFFERENTIAL ACROSS THE HEPA FILTER THE PRESSURE DIFFERENTIAL ACROSS THE FILTER SHALL BE RECORDED AT THE BEGINNING OF EACH DAY OF USE AND IMMEDIATELY AFTER ANY FILTER CHANGE THE PRESSURE DIFFERENTIAL SHALL BE CHECKED PERIODICALLY AND THE PRESSURE DIFFERENTIAL SHALL NOT BE LESS THAN THE INITIAL READING (READING AT THE BEGINNING OF EACH DAY OF USE OR READING AFTER ANY FILTER CHANGE) IN THE EVENT THAT THE PRESSURE DIFFERENTIAL IS LESS THAN THE INITIAL READING THE NEGATIVE AIR MACHINE SHALL BE TURNED-OFF AND SHALL BE CHECKED FOR LEAKAGE AND RUPTURE OF THE HEPA FILTER
[RULE 1403]
- 10 A MECHANICAL GAUGE SHALL BE INSTALLED SO AS TO INDICATE IN INCHES OF WATER COLUMN, THE PRESSURE DIFFERENTIAL BETWEEN THE CONTAINMENT AND THE OUTSIDE THE MECHANICAL GAUGE SHALL BE LOCATED IN A MANNER THAT WILL ALLOW AN OBSERVER TO EASILY MONITOR THE DIFFERENTIAL PRESSURE FROM OUTSIDE OF THE CONTAINMENT
[RULE 1403]
- 11 THE MINIMUM PRESSURE DIFFERENTIAL BETWEEN THE CONTAINMENT AND THE OUTSIDE SHALL BE 0.02 INCH OF WATER GAUGE TO PREVENT ASBESTOS FIBERS FROM ESCAPING THE CONTAINMENT BARRIERS AND TO ENSURE THAT THE NEGATIVE AIR MACHINE AIRFLOW IS ADEQUATE
[RULE 1403]
- 12 THE OPERATOR SHALL KEEP ADEQUATE RECORDS FOR THIS NEGATIVE AIR MACHINE TO VERIFY
 - 1) THE NUMBER OF WORKING HOURS PER DAY INVOLVING ASBESTOS REMOVAL AND
 - 2) THE EXHAUST CONCENTRATION INCLUDING THE TIME AND DATE OF EACH SAMPLING AND
 - 3) THE PRESSURE GAUGE READING AT THE BEGINNING OF EACH DAY OF USE AND AFTER EACH CHANGE OF HEPA FILTER INCLUDING THE TIME AND DATE OF THE READING AND
 - 4) THE DATE AND TIME OF EACH HEPA FILTER REPLACEMENT AND
 - 5) THE DATE AND TIME OF EACH MACHINE ADDITION/REPLACEMENTSUCH RECORDS SHALL BE
 - 1 RETAINED FOR A PERIOD OF TWO YEARS AND
 - 2 MADE AVAILABLE UPON REQUEST BY THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

[RULE 1403]

- 13 THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE SHALL BE NOTIFIED AND A WRITTEN APPROVAL SHALL BE OBTAINED PRIOR TO COMMENCEMENT OF ANY ABATEMENT PROJECT
- 1) THE VOLUME OF WHICH WILL EXCEED THE TOTAL MACHINE(S) EXHAUST VOLUME SPECIFIED IN CONDITIONS 4 OR 5 OR
- 2) LOCATED WITHIN 1 000 FEET FROM THE OUTER BOUNDARY OF A SCHOOL
- [RULE 1403]

Emissions And Requirements

- 14 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- ASBESTOS RULE 1403



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

**Permit No F46186
A/N 392662**

Equipment Description

INTERNAL COMBUSTION ENGINE JOHN DEERE MODEL 6068T DIESEL FUEL SIX CYLINDERS
TURBOCHARGED, RATED AT 166 B H P DRIVING AN EMERGENCY ELECTRICAL GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a) RULE 1110 2, RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR
[RULE 1470]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS
- A EMERGENCY USE HOURS OF OPERATION
 - B MAINTENANCE AND TESTING HOURS
 - C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)
- IN ADDITION EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431 2 AND 1470
[RULE 431 2, RULE 1470]

Emissions And Requirements

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS
 - PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

**Permit No F48207
A/N 393684**

Equipment Description

UNCONFINED PORTABLE ABRASIVE BLASTING SYSTEM CONSISTING OF

- 1 ABRASIVE BLASTING POT EMPIRE ABRASIVE EQUIPMENT CO, MODEL BNVP 300
- 2 COMPRESSOR ELECTRIC 60 H P
- 3 ONE ABRASIVE BLASTING NOZZLE WITH A MAXIMUM INTERNAL DIAMETER OF 1/4 INCH AT A MAXIMUM DELIVERY PRESSURE OF 150 PSIA

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 THIS EQUIPMENT SHALL COMPLY WITH RULE 1140
[RULE 1140]

Periodic Monitoring

- 4 THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS WHENEVER VISIBLE EMISSIONS ARE OBSERVED AND ON AN ANNUAL BASIS, AT LEAST UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THAT LAST MORE THAN THREE MINUTES IN ANY ONE HOUR THE OPERATOR SHALL EITHER
 - A VERIFY AND CERTIFY WITHIN 24 HOURS THAT THE EQUIPMENT CAUSING THE EMISSION AND ANY ASSOCIATED AIR POLLUTION CONTROL EQUIPMENT ARE OPERATING NORMALLY ACCORDING TO THEIR DESIGN AND STANDARD PROCEDURES AND UNDER THE SAME CONDITIONS UNDER WHICH COMPLIANCE WAS ACHIEVED IN THE PAST
 - B TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 15 THE STATIC PRESSURE LEAK DECAY TEST TP-201.3 SHALL BE CONDUCTED IN ACCORDANCE WITH EXHIBIT 8 OF CARB EXECUTIVE ORDER VR-202-F. VERIFICATION OF COMPLETING EACH STEP AS OUTLINED SHALL BE DOCUMENTED BY SUBMITTING A COPY OF EXHIBIT 8 TO THE AQMD OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY TWO (72) HOURS OF TEST
RULE 461]
- 16 A CARB CERTIFIED PHASE II ENHANCED VAPOR RECOVERY SYSTEM SHALL BE FULLY PERMITTED, INSTALLED AND TESTED BY OCTOBER 1 2008. FAILURE TO ACHIEVE THIS CONDITION BY OCTOBER 1 2008 SHALL RESULT IN THE OWNER/OPERATOR TO FILE A DISTRICT APPROVED COMPLIANCE PLAN OUTLINING THE INCREMENTS OF PROGRESS TOWARDS COMPLETING THE INSTALLATION OF A CARB CERTIFIED PHASE II ENHANCED VAPOR RECOVERY SYSTEM BY APRIL 1 2009
RULE 461]
- 17 IF THE OWNER/OPERATOR PLANS TO PERMANENTLY CEASE ALL GASOLINE DISPENSING OPERATIONS BEFORE APRIL 1, 2009, A COMPLIANCE PLAN SHALL BE FILED DECLARING TO IRREVOCABLY SURRENDER THEIR PERMIT TO OPERATE
RULE 461]
- 18 THE AQMD SHALL BE NOTIFIED BY E MAIL AT R461TESTING@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396 3606 AT LEAST SEVENTY-TWO (72) HOURS PRIOR TO ANY OF THE ABOVE MENTIONED TESTING REQUIREMENTS. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR, THE NAME OF THE CONTRACTOR, THE LOCATION OF THE FACILITY, AND THE SCHEDULED START AND COMPLETION DATES OF THE TESTS TO BE PERFORMED
RULE 461]
- 19 THE TESTING FOR THE ABOVE MENTIONED TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH THE MOST RECENT RULE 461 AMENDMENT OR CARB EXECUTIVE ORDER REQUIREMENTS, WHICHEVER IS MORE STRINGENT
RULE 461]
- 20 ALL RECORDS AND TEST RESULTS THAT ARE REQUIRED TO BE MAINTAINED BY RULE 461 SHALL BE KEPT ON SITE FOR FOUR YEARS AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST
RULE 461]
- 21 SHOULD THE FACILITY DISPENSE MORE THAN 600 000 GALLONS OF GASOLINE PER CALENDAR YEAR AND IF THE FACILITY UNDERGOES A MAJOR MODIFICATION AS DEFINED BY CARB'S ADVISORY LETTER NUMBER 336, ENHANCED VAPOR RECOVERY IMPLEMENTATION UPDATE DATED APRIL 15 2005, THE OPERATOR SHALL IMMEDIATELY CEASE ALL GASOLINE DISPENSING OPERATIONS AND FILE AN APPLICATION FOR A NEW PERMIT TO CONSTRUCT/OPERATE TO INSTALL A CARB CERTIFIED ISD SYSTEM. GASOLINE DISPENSING OPERATIONS SHALL NOT RESUME UNTIL THE ISD SYSTEM HAS BEEN GRANTED A PERMIT TO CONSTRUCT/OPERATE AND HAS BEEN FULLY INSTALLED, TESTED, AND OPERATIVE
RULE 461]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 22 SHOULD THE FACILITY DISPENSE MORE THAN 600 000 GALLONS OF GASOLINE IN ANY CALENDAR YEAR AND IF THE FACILITY DOES NOT UNDERGO A MAJOR MODIFICATION AS DEFINED BY CARB'S ADVISORY LETTER NUMBER 336 'ENHANCED VAPOR RECOVERY IMPLEMENTATION UPDATE' DATED APRIL 15 2005 THE OPERATOR SHALL FILE AN APPLICATION FOR A NEW PERMIT TO CONSTRUCT/OPERATE TO INSTALL A CARB CERTIFIED ISD SYSTEM THE ISD SYSTEM SHALL BE FULLY INSTALLED, TESTED AND OPERATIVE BASED ON THE FOLLOWING TABLE

<u>GASOLINE THROUGHPUT PER CALENDAR YEAR</u>	<u>DATE</u>
GREATER THAN 1 8 MILLION GALLONS	SEPTEMBER 1 2009
BETWEEN 600 000 AND 1 8 MILLION GALLONS	SEPTEMBER 1 2010

RULE 461]

- 23 THE MAXIMUM QUANTITY OF GASOLINE DISPENSED FROM THE STORAGE TANKS AT THIS FACILITY SHALL NOT EXCEED 21 000 GALLONS IN ANY ONE CALENDAR MONTH NOR 252 000 GALLONS IN ANY ONE CALENDAR YEAR
[RULE 1303 (b)(2) OFFSETS RULE 1401]
- 24 RECORDS OF MONTHLY AND ANNUAL FUEL DISPENSED SHALL BE PREPARED SHALL BE RETAINED ON SITE FOR FIVE YEARS, AND SHALL BE MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST
[RULE 1303 (b)(2)-OFFSETS RULE 1401]

Periodic Monitoring

- 25 THE OPERATOR SHALL HAVE A PERSON THAT HAS BEEN TRAINED IN ACCORDANCE WITH RULE 461(d)(5) CONDUCT A SEMI ANNUAL INSPECTION OF THE GASOLINE TRANSFER AND DISPENSING EQUIPMENT THE FIRST INSPECTION SHALL BE IN ACCORDANCE WITH RULE 461 ATTACHMENT B THE SECOND INSPECTION SHALL BE IN ACCORDANCE WITH RULE 461 ATTACHMENT C AND THE SUBSEQUENT INSPECTIONS SHALL ALTERNATE PROTOCOLS THE OPERATOR SHALL KEEP RECORDS OF THE INSPECTION AND THE REPAIRS IN ACCORDANCE TO RULE 461 AND SECTION K OF THIS PERMIT
[RULE 3004 (a)(4)]

Emissions And Requirements

- 26 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- VOC RULE 461
VOC RULE 1170



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No G7128
A/N 503477

Equipment Description

INTERNAL COMBUSTION ENGINE, MTU DETROIT DIESEL MODEL R123-8A36 DIESEL FUEL 12 CYLINDERS TURBOCHARGED AND AFTERCOOLED RATED AT 1120 B H P DRIVING AN EMERGENCY ELECTRICAL GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a), RULE 1110 2 RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR
[RULE 1470]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS
- A EMERGENCY USE HOURS OF OPERATION
 - B MAINTENANCE AND TESTING HOURS
 - C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)
- IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
[RULE 1304 (a) RULE 1110.2 RULE 1470]
- 8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431.2 AND 1470
[RULE 431.2 RULE 1470]

Emissions And Requirements

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS
 - PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

RULE 219 EQUIPMENT

Equipment Description

RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE ARCHITECTURAL COATINGS

Periodic Monitoring

- 1 THE OPERATOR SHALL KEEP RECORDS IN A MANNER APPROVED BY THE DISTRICT FOR THE FOLLOWING PARAMETER(S) OR ITEM(S)

FOR ARCHITECTURAL APPLICATIONS WHERE NO THINNERS REDUCERS, OR OTHER VOC CONTAINING MATERIALS ARE ADDED MAINTAIN RECORDS OF ALL COATINGS THAT ARE NOT CLEARLY LABELED AS COMPLYING WITH SCAQMD RULE 1113 COMPLIANCE IN THESE CASES SHALL BE DETERMINED BY MAINTAINING RECORDS OF MANUFACTURERS CERTIFICATIONS OR BY MATERIAL SAFETY DATA SHEETS (MSDS) THAT DEMONSTRATE COMPLIANCE WITH THE VOC LIMITS OF THE TYPE OF COATING USED IN RULE 1113 PERIODIC INSPECTIONS OF ALL ARCHITECTURAL COATING OPERATIONS SHALL BE CONDUCTED AND DOCUMENTED TO INSURE COMPLIANCE WITH THE PROVISIONS OF THIS RULE

FOR OTHER ARCHITECTURAL APPLICATIONS WHERE THINNERS REDUCERS OR OTHER VOC CONTAINING MATERIALS ARE ADDED MAINTAIN DAILY RECORDS FOR EACH COATING CONSISTING OF (a) COATING TYPE (b) VOC CONTENT AS APPLIED IN GRAMS PER LITER (g/l) OF MATERIALS USED FOR LOW SOLIDS COATINGS (c) VOC CONTENT AS APPLIED IN g/l OF COATING LESS WATER AND EXEMPT SOLVENT FOR OTHER COATING

[RULE 3004 (a) (4)]

Emissions And Requirements

- 2 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION

VOC RULE 1113 SEE APPENDIX B FOR EMISSION LIMITS
VOC RULE 1171 SEE APPENDIX B FOR EMISSION LIMITS



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

RULE 219 EQUIPMENT

Equipment Description

RULE 219 EXEMPT EQUIPMENT HAND WIPING OPERATIONS

Emissions And Requirements

- 1 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION

VOC RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS

RULE 219 EQUIPMENT

Equipment Description

RULE 219 EXEMPT EQUIPMENT BOILER > 400 000 BTU/HR BUT < 2 MMBTU/HR

Emissions And Requirements

- 1 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS

PM 0.1 gr/scf RULE 409
NOx 30 PPMV RULE 1146.2
CO 400 PPMV RULE 1146.2
CO 2000 PPMV, RULE 407



FACILITY PERMIT TO OPERATE MCA/UNIVERSAL STUDIOS

RULE 219 EQUIPMENT

Equipment Description

RULE 219 EXEMPT EQUIPMENT ABRASIVE BLASTING EQUIPMENT GLOVE BOX < 53 FT³, WITH DUST FILTER

Periodic Monitoring

- 1 THE OPERATOR SHALL PERFORM AN ANNUAL INSPECTION OF THE EQUIPMENT AND FILTER MEDIA FOR LEAKS BROKEN OR TORN FILTER MEDIA AND IMPROPERLY INSTALLED FILTER MEDIA THE OPERATOR SHALL KEEP RECORDS IN A MANNER APPROVED BY THE DISTRICT FOR THE FOLLOWING PARAMETER(S) OR ITEM(S)
 - A THE NAME OF THE PERSON PERFORMING THE INSPECTION AND/OR MAINTENANCE OF THE FILTER MEDIA
 - B THE DATE TIME AND RESULTS OF THE INSPECTION AND
 - C THE DATE TIME AND DESCRIPTION OF ANY MAINTENANCE OR REPAIRS RESULTING FROM THE INSPECTION
[RULE 3004 (a)(4)]
- 2 THE OPERATOR SHALL DISCHARGE DUST COLLECTED IN THIS EQUIPMENT ONLY INTO CLOSED CONTAINERS
[RULE 3004 (a)(4)]
- 3 THE OPERATOR SHALL CONDUCT AN INSPECTION FOR VISIBLE EMISSIONS FROM ALL STACKS AND OTHER EMISSION POINTS OF THIS EQUIPMENT WHENEVER THERE IS A PUBLIC COMPLAINT OF VISIBLE EMISSIONS WHENEVER VISIBLE EMISSIONS ARE OBSERVED AND ON AN ANNUAL BASIS AT LEAST UNLESS THE EQUIPMENT DID NOT OPERATE DURING THE ENTIRE ANNUAL PERIOD THE ROUTINE ANNUAL INSPECTION SHALL BE CONDUCTED WHILE THE EQUIPMENT IS IN OPERATION AND DURING DAYLIGHT HOURS IF ANY VISIBLE EMISSIONS (NOT INCLUDING CONDENSED WATER VAPOR) ARE DETECTED THE OPERATOR SHALL TAKE CORRECTIVE ACTION(S) THAT ELIMINATES THE VISIBLE EMISSIONS WITHIN 24 HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT
THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS
 - A STACK OR EMISSION POINT IDENTIFICATION
 - B DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS AND
 - C DATE AND TIME VISIBLE EMISSION WAS ABATED
[RULE 3004 (a)(4)]

Emissions And Requirements



FACILITY PERMIT TO OPERATE MCA/UNIVERSAL STUDIOS

- 4 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS

PM	RULE 404, SEE APPENDIX B FOR EMISSION LIMITS
PM	RULE 405 SEE APPENDIX B FOR EMISSION LIMITS
PM	RULE 1140, SEE APPENDIX B FOR EMISSION LIMITS



FACILITY PERMIT TO OPERATE MCA/UNIVERSAL STUDIOS

RULE 219 EQUIPMENT

Equipment Description

RULE 219 EXEMPT EQUIPMENT PRINTING EQUIPMENT

Emissions And Requirements

- 1 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATION

VOC RULE 1130 SEE APPENDIX B FOR EMISSION LIMITS
VOC RULE 1130 1 SEE APPENDIX B FOR EMISSION LIMITS
VOC RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS



FACILITY PERMIT TO OPERATE MCA/UNIVERSAL STUDIOS

RULE 219 EQUIPMENT

Equipment Description

RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT LOW USE OR EMISSIONS

Emissions And Requirements

- 1 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
 - VOC RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS
 - VOC RULE 1107, SEE APPENDIX B FOR EMISSION LIMITS
 - VOC RULE 1136 SEE APPENDIX B FOR EMISSION LIMITS
 - VOC RULE 1168 SEE APPENDIX B FOR EMISSION LIMITS
 - VOC RULE 1145 SEE APPENDIX B FOR EMISSION LIMITS
 - VOC RULE 1151, SEE APPENDIX B FOR EMISSION LIMITS
 - VOC RULE 1106 I, SEE APPENDIX B FOR EMISSION LIMITS
 - VOC RULE 109



FACILITY PERMIT TO OPERATE MCA/UNIVERSAL STUDIOS

RULE 219 EQUIPMENT

Equipment Description

RULE 219 EXEMPT EQUIPMENT, HAND RESIN LAY UP

Emissions And Requirements

- 1 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
 - VOC RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS
 - VOC RULE 1162, SEE APPENDIX B FOR EMISSION LIMITS



FACILITY PERMIT TO OPERATE MCA/UNIVERSAL STUDIOS

RULE 219 EQUIPMENT

Equipment Description

RULE 219 EXEMPT EQUIPMENT CLEANING EQUIPMENT SMALL UNHEATED NON CONVEYORIZED

Emissions And Requirements

- 1 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
VOC RULE 1122
VOC RULE 1171, SEE APPENDIX B FOR EMISSION LIMITS



FACILITY PERMIT TO OPERATE MCA/UNIVERSAL STUDIOS

RULE 219 EQUIPMENT

Equipment Description

RULE 219 EXEMPT EQUIPMENT AIR CONDITIONING UNITS

Emissions And Requirements

- 1 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS

REFRIGERANT	RULE 1415
REFRIGERANT	40CFR 82 SUBART F



FACILITY PERMIT TO OPERATE MCA/UNIVERSAL STUDIOS

RULE 219 EQUIPMENT

Equipment Description

RULE 219 EXEMPT EQUIPMENT, REFRIGERATION UNITS

Emissions And Requirements

- 1 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS

REFRIGERANT	RULE 1415
REFRIGERANT	40CFR 82 SUBART F



FACILITY PERMIT TO OPERATE MCA/UNIVERSAL STUDIOS

RULE 219 EQUIPMENT

Equipment Description

RULE 219 EXEMPT EQUIPMENT FIRE EXTINGUISHING EQUIPMENT

Emissions And Requirements

- 1 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS

HALON RULE 1418



FACILITY PERMIT TO OPERATE MCA/UNIVERSAL STUDIOS

RULE 219 EQUIPMENT

Equipment Description

RULE 219 EQUIPMENT ASBESTOS NEGATIVE AIR MACHINE WITH HEPA FILTER < 15 GALLONS

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS FILING IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 FOR EACH RESIDENTIAL ABATEMENT PROJECT THE NEGATIVE AIR MACHINE(S) EXHAUST SHALL BE LOCATED A MINIMUM OF 3 METERS (10 FEET) FROM THE NEAREST RECEPTOR (ANY LOCATION WHERE THE PUBLIC CAN BE EXPOSED TO ASBESTOS FIBER EMISSIONS) AND SHALL BE LOCATED AT LEAST 4 FEET ABOVE THE GROUND
[RULE 1403]
- 4 FOR EACH RESIDENTIAL ABATEMENT PROJECT THE NEGATIVE AIR MACHINE(S) SHALL NOT EXHAUST MORE THAN A COMBINED TOTAL OF 4 8 MILLION CUBIC FEET OF AIR (THE TOTAL RATED AIR FLOW OF ALL MACHINE(S) IN CUBIC FEET PER MINUTE MULTIPLIED BY THE TOTAL NUMBER OF WORKING HOURS INVOLVING ASBESTOS REMOVAL)
[RULE 1403]
- 5 FOR EACH COMMERCIAL ABATEMENT PROJECT THE NEGATIVE AIR MACHINE(S) EXHAUST SHALL BE LOCATED A MINIMUM OF 3 METERS (10 FEET) FROM THE NEAREST RECEPTOR (ANY LOCATION WHERE THE PUBLIC CAN BE EXPOSED TO ASBESTOS FIBER EMISSIONS) AND SHALL BE LOCATED AT LEAST 10 FEET ABOVE THE GROUND
[RULE 1403]
- 6 FOR EACH COMMERCIAL ABATEMENT PROJECT LOCATED MORE THAN 3 METERS (10 FEET) BUT LESS THAN 30 METERS (98 FEET) FROM ANY RESIDENTIAL ZONING THE NEGATIVE AIR MACHINE(S) SHALL NOT EXHAUST MORE THAN A COMBINED TOTAL OF 4 8 MILLION CUBIC FEET OF AIR (THE TOTAL RATED AIR FLOW OF ALL MACHINE(S) IN CUBIC FEET PER MINUTE MULTIPLIED BY THE TOTAL NUMBER OF WORKING HOURS INVOLVING ASBESTOS REMOVAL)
[RULE 1403]



FACILITY PERMIT TO OPERATE MCA/UNIVERSAL STUDIOS

- 7 FOR EACH COMMERCIAL ABATEMENT PROJECT LOCATED GREATER THAN OR EQUAL TO 30 METERS (98 FEET) FROM ANY RESIDENTIAL ZONING THE NEGATIVE AIR MACHINE(S) SHALL NOT EXHAUST AIR IN WHICH THE COMBINED TOTAL AIR VOLUME (THE TOTAL RATED AIR FLOW OF ALL MACHINE(S) IN CUBIC FEET PER MINUTE MULTIPLIED BY THE TOTAL NUMBER OF WORKING HOURS INVOLVING ASBESTOS REMOVAL) WILL EXCEED THE AMOUNT SPECIFIED ON TABLE 1
[RULE 1403]

TABLE 1

DISTANCE (METERS) TO RESIDENTIAL	DISTANCE (FEET) TO RESIDENTIAL	AIR VOLUME (MILLION CUBIC FEET)
30 to < 35	98 to < 115	7 7
35 to < 40	115 to < 131	9 9
40 to < 45	131 to < 148	13 8
45 to < 50	148 to < 164	18 8
50 to < 55	164 to < 180	24 1
55 to < 60	180 to < 197	32 1
60 to < 65	197 to < 213	40 8
65 to < 70	213 to < 230	51 0
70 to < 75	230 to < 246	62 8
75 to < 80	246 to < 262	76 5
80 to < 85	262 to < 279	92 2
85 to < 90	279 to < 295	110 0
90 to < 95	295 to < 312	130 0
95 to < 100	312 to < 328	153 0
100 to < 105	328 to < 344	179 0
105 to < 110	344 to < 361	217 0
110 to < 115	361 to < 377	250 0
115 to < 120	377 to < 394	286 0
120 to < 125	394 to < 410	325
125 to < 130	410 to < 427	368 0
130 to < 135	427 to < 443	415 0
135 to < 140	443 to < 459	465 0
140 and greater	459 and greater	520 0

- 8 FOR EACH ABATEMENT PROJECT THE EXHAUST OF EACH NEGATIVE AIR MACHINE SHALL BE ANALYZED BY THE PHASE CONTRAST MICROSCOPY (PCM) METHOD DURING THE FIRST DAY OF ACTUAL ASBESTOS REMOVAL AND AFTER EACH HEPA FILTER REPLACEMENT IF THIS NEGATIVE AIR MACHINE IS ADDED OR REPLACED DURING A SPECIFIC PROJECT THE EXHAUST OF THIS ADDITION OR REPLACEMENT SHALL BE ANALYZED BY THE PCM METHOD DURING THE FIRST DAY OF ITS USE DURING ACTUAL ASBESTOS REMOVAL EXHAUST SAMPLES TO BE ANALYZED SHALL ONLY BE TAKEN DURING ACTUAL ASBESTOS REMOVAL



FACILITY PERMIT TO OPERATE MCA/UNIVERSAL STUDIOS

DURING EACH LONG TERM ABATEMENT PROJECT (GREATER THAN 15 CALENDAR DAYS) THE EXHAUST OF EACH NEGATIVE AIR MACHINE SHALL BE ANALYZED AT LEAST EVERY 15 CALENDAR DAYS
[RULE 1403]

- 9 THE EXHAUST CONCENTRATION OF ASBESTOS FROM THE NEGATIVE AIR MACHINE SHALL NOT EXCEED 0.01 FIBER PER CUBIC CENTIMETER
[RULE 1403]
- 10 THE NEGATIVE AIR MACHINE SHALL BE TESTED FOR LEAKAGE AFTER EACH HEPA FILTER CHANGE AND PRIOR TO COMMENCEMENT OF ANY ABATEMENT PROJECT
[RULE 1403]
- 11 A PRESSURE GAUGE SHALL BE MAINTAINED TO INDICATE IN INCHES OF WATER COLUMN THE PRESSURE DIFFERENTIAL ACROSS THE HEPA FILTER. THE PRESSURE DIFFERENTIAL ACROSS THE FILTER SHALL BE RECORDED AT THE BEGINNING OF EACH DAY OF USE AND IMMEDIATELY AFTER ANY FILTER CHANGE. THE PRESSURE DIFFERENTIAL SHALL BE CHECKED PERIODICALLY AND THE PRESSURE DIFFERENTIAL SHALL NOT BE LESS THAN THE INITIAL READING (READING AT THE BEGINNING OF EACH DAY OF USE OR READING AFTER ANY FILTER CHANGE). IN THE EVENT THAT THE PRESSURE DIFFERENTIAL IS LESS THAN THE INITIAL READING, THE NEGATIVE AIR MACHINE SHALL BE TURNED OFF AND SHALL BE CHECKED FOR LEAKAGE AND RUPTURE OF THE HEPA FILTER
[RULE 1403]
- 12 A MECHANICAL GAUGE SHALL BE INSTALLED SO AS TO INDICATE IN INCHES OF WATER COLUMN, THE PRESSURE DIFFERENTIAL BETWEEN THE CONTAINMENT AND THE OUTSIDE. THE MECHANICAL GAUGE SHALL BE LOCATED IN A MANNER THAT WILL ALLOW AN OBSERVER TO EASILY MONITOR THE DIFFERENTIAL PRESSURE FROM OUTSIDE OF THE CONTAINMENT
[RULE 1403]
- 13 THE MINIMUM PRESSURE DIFFERENTIAL BETWEEN THE CONTAINMENT AND THE OUTSIDE SHALL BE 0.02 INCH OF WATER GAUGE TO PREVENT ASBESTOS FIBERS FROM ESCAPING THE CONTAINMENT BARRIERS AND TO ENSURE THAT THE NEGATIVE AIR MACHINE AIRFLOW IS ADEQUATE
[RULE 1403]
- 14 THE OPERATOR SHALL KEEP ADEQUATE RECORDS FOR THIS NEGATIVE AIR MACHINE TO VERIFY
 - 1) THE NUMBER OF WORKING HOURS PER DAY INVOLVING ASBESTOS REMOVAL, AND
 - 2) THE EXHAUST CONCENTRATION INCLUDING THE TIME AND DATE OF EACH SAMPLING AND
 - 3) THE PRESSURE GAUGE READING AT THE BEGINNING OF EACH DAY OF USE AND AFTER EACH CHANGE OF HEPA FILTER INCLUDING THE TIME AND DATE OF THE READING AND
 - 4) THE DATE AND TIME OF EACH HEPA FILTER REPLACEMENT AND



FACILITY PERMIT TO OPERATE MCA/UNIVERSAL STUDIOS

- 5) THE DATE AND TIME OF EACH MACHINE ADDITION/REPLACEMENT
SUCH RECORDS SHALL BE
- 1 RETAINED FOR A PERIOD OF TWO YEARS AND
 - 2 MADE AVAILABLE UPON REQUEST BY THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE
- [RULE 1403]
- 15 THE EXECUTIVE OFFICER OR HIS REPRESENTATIVE SHALL BE NOTIFIED AND A WRITTEN APPROVAL SHALL BE OBTAINED PRIOR TO COMMENCEMENT OF ANY ABATEMENT PROJECT
- 1) THE VOLUME OF WHICH WILL EXCEED THE TOTAL MACHINE(S) EXHAUST VOLUME SPECIFIED IN CONDITIONS 4, 6 OR 7, OR
 - 2) LOCATED WITHIN 1 000 FEET FROM THE OUTER BOUNDARY OF A SCHOOL
- [RULE 1403]

Emissions And Requirements

- 16 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- ASBESTOS RULE 1403



FACILITY PERMIT TO OPERATE MCA/UNIVERSAL STUDIOS

RULE 219 EQUIPMENT

Equipment Description

RULE 219 EXEMPT EQUIPMENT, CHARBROILERS

Conditions

For all charbroilers

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS FILING IS ISSUED UNLESS OTHERWISE NOTED BELOW
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
- 3 THIS EQUIPMENT SHALL BE OPERATED CLEANED AND MAINTAINED IN ACCORDANCE WITH THE MANUFACTURER'S SPECIFICATION IN ITS MAINTENANCE MANUAL OR ANY WRITTEN BULLETIN SUPPLIED BY THE MANUFACTURER/DISTRIBUTOR OF THE EQUIPMENT

For equipment operating with an air pollution control device the following parameters also apply

- 4 THE CHARBROILER SHALL NOT BE OPERATED UNLESS IT IS PROPERLY VENTED TO THE AIR POLLUTION CONTROL DEVICE WHICH IS IN FULL USE AND WHICH IS MAINTAINED IN ACCORDANCE WITH THE MANUFACTURER'S SPECIFICATIONS IN ITS MAINTENANCE MANUAL OR ANY WRITTEN BULLETIN SUPPLIED BY THE MANUFACTURER/DISTRIBUTOR OF THE AIR POLLUTION CONTROL DEVICE OR CHARBROILER
- 5 AN OPERATING RECORD OF THE CHARBROILER AND CONTROL DEVICE SHALL BE MAINTAINED IN A WRITTEN FORMAT APPROVED IN WRITING BY THE EXECUTIVE OFFICER THE RECORD SHALL INCLUDE AT A MINIMUM MAINTENANCE RECORDS FOR THE EQUIPMENT
- 6 THE RECORDS SHALL BE KEPT FOR A MINIMUM OF ONE YEAR AND MADE AVAILABLE UPON REQUEST OF AQMD PERSONNEL

For all commercial chain-driven charbroilers, the following parameter applies

- 7 RECORDS SHALL BE MAINTAINED IN ACCORDANCE WITH THE REQUIREMENTS OF RULE 1138- CONTROL OF EMISSIONS FROM RESTAURANT OPERATIONS



FACILITY PERMIT TO OPERATE MCA/UNIVERSAL STUDIOS

Emissions And Requirements

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES
AND REGULATIONS

PM 1138



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

HOURS AND REPORT THE VISIBLE EMISSIONS AS A POTENTIAL DEVIATION IN ACCORDANCE WITH THE REPORTING REQUIREMENTS IN SECTION K OF THIS PERMIT OR

- C HAVE A CARB-CERTIFIED SMOKE READER DETERMINE COMPLIANCE WITH THE OPACITY STANDARD, USING EPA METHOD 9 OR THE PROCEDURES IN THE CARB MANUAL VISIBLE EMISSION EVALUATION, WITHIN THREE BUSINESS DAYS AND REPORT ANY DEVIATIONS TO AQMD

THE OPERATOR SHALL KEEP THE RECORDS IN ACCORDANCE WITH THE RECORDKEEPING REQUIREMENTS IN SECTION K OF THIS PERMIT AND THE FOLLOWING RECORDS

- A STACK OR EMISSION POINT IDENTIFICATION
 - B DESCRIPTION OF ANY CORRECTIVE ACTIONS TAKEN TO ABATE VISIBLE EMISSIONS
 - C DATE AND TIME VISIBLE EMISSION WAS ABATED AND
 - D VISIBLE EMISSION OBSERVATION RECORDED BY A CERTIFIED SMOKE READER
[RULE 3004 (a)(4)]
- 5 MAINTAIN DAILY RECORDS OF ABRASIVE USED AND EVIDENCE OF ARB CERTIFICATION
[RULE 3004 (a)(4)]
- 6 MAINTAIN RECORDS TO DEMONSTRATE THAT REUSED ABRASIVE ARE TESTED WITH CARB METHOD 371 A
[RULE 3004 (a)(4)]
- 7 MAINTAIN DAILY RECORDS OF DESCRIPTION OF ITEMS BLASTED TO DEMONSTRATE COMPLIANCE
[RULE 3004 (a)(4)]

Emissions And Requirements

- 8 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- PM RULE 1140 SEE APPENDIX B FOR EMISSION LIMITS



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F52607
A/N 402105

Equipment Description

INTERNAL COMBUSTION ENGINE CATERPILLAR, MODEL 3056T (80 KW) DIESEL FUEL
TURBOCHARGED RATED AT 128 B H P DRIVING AN EMERGENCY ELECTRICAL GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a), RULE 1110 2 RULE 1470]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 20 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 20 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

[RULE 1470]

- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS
- A EMERGENCY USE HOURS OF OPERATION
 - B MAINTENANCE AND TESTING HOURS
 - C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)
- IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
- [RULE 1304 (a) RULE 1110 2 RULE 1470]
- 8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431 2 AND 1470
- [RULE 431 2 RULE 1470]

Emissions And Requirements

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS
 - PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F48611
A/N 396217

Equipment Description

FILM CLEANING MACHINE LIPSNER SMITH MODEL EXCEL 1100 SERIAL NO 20129 2-6' W X 0 7 L X
4-3" H

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 THIS EQUIPMENT SHALL NOT BE OPERATED UNLESS IT IS VENTED TO AN AIR POLLUTION CONTROL SYSTEM WHICH IS IN FULL USE AND HAS BEEN ISSUED AN OPERATING PERMIT BY THE EXECUTIVE OFFICER
[RULE 1303 (a) BACT]
- 4 THIS EQUIPMENT SHALL ONLY USE HYDROTREATED NAPHTHA AS THE CLEANING SOLVENT
[RULE 1303 (a)-BACT]
- 5 THE MAXIMUM AMOUNT OF CLEANING SOLVENT USED IN THIS EQUIPMENT SHALL NOT EXCEED 30 GALLONS IN ANY ONE CALENDAR MONTH
[RULE 1303 (b)(2)]
- 6 MATERIAL SAFETY DATA SHEETS FOR THE CLEANING SOLVENT SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1303 (a)-BACT]
- 7 RECORDS SHALL BE MAINTAINED TO PROVE COMPLIANCE WITH CONDITION NO 4 AND 5 THE RECORDS SHALL BE KEPT FOR AT LEAST TWO YEARS AND SHALL BE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1303 (b)(2)]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

**Permit No F48612
A/N 396218**

Equipment Description

AIR POLLUTION CONTROL SYSTEM CONSISTING OF

- 1 CARBON ADSORBERS TWO IN SERIES US FILTER/WESTATES, MODEL VSC-1000 EACH 4'-0" DIA X 4' 8" H WITH 1000 POUNDS OF ACTIVATED CARBON
- 2 EXHAUST SYSTEM WITH ONE 5 HP BLOWER 210 MAX CFM VENTING ONE FILM CLEANING MACHINE

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 A FLOW INDICATOR SHALL BE INSTALLED AND MAINTAINED AT THE INLET STREAM TO THE VAPOR CONTROL SYSTEM TO INDICATE THE TOTAL AIR FLOW RATE IN CUBIC FEET PER MINUTE (CFM) THE TOTAL FLOW RATE SHALL NOT EXCEED 210 SCFM IN CASE A PRESSURE SENSOR DEVICE IS USED IN PLACE OF THE FLOW INDICATOR A CONVERSION CHART SHALL BE POSTED ON THE EQUIPMENT TO INDICATE THE CORRESPONDING FLOW RATE IN CFM TO THE PRESSURE READING
[RULE 1303 (a) BACT]
- 4 VOLATILE ORGANIC COMPOUND (VOC) CONCENTRATION SHALL BE MEASURED AT THE OUTLET OF THE PRIMARY CARBON ADSORBER AND SECONDARY ADSORBER AT LEAST ONCE A MONTH BY USING A FLAME IONIZATION DETECTOR OR A DISTRICT APPROVED ORGANIC VAPOR ANALYZER (OVA) CALIBRATED IN PARTS PER MILLION BY VOLUME (PPMV) OF HEXANE (IF OTHER CALIBRATING AGENT IS USED IT SHALL BE CORRELATED TO AND EXPRESSED AS HEXANE) IN LIEU OF USING A VAPOR ANALYZER GRAB SAMPLES MAY BE TAKEN AT THE OUTLET OF THE PRIMARY CARBON ADSORBER THE RESULTS OF THE GRAB SAMPLE ANALYSIS SHALL BE COMPLETED BEFORE THE NEXT SCHEDULED MONITORING OF THE CARBON ADSORBER
[RULE 1303 (a) BACT]



**FACILITY PERMIT TO OPERATE
UNIVERSAL CITY STUDIOS, LLC**

- 5 THE VOC OUTLET CONCENTRATION AT THE SECONDARY CARBON ADSORBER SHALL NOT EXCEED 52 PPMV AS HEXANE
[RULE 1303 (a)-BACT]
- 6 WHENEVER THE VOC CONCENTRATION AT THE OUTLET OF THE PRIMARY CARBON ADSORBER EXCEEDS THE LEVEL IN CONDITION 5 THE ADSORBERS SHALL BE REPLACED AS FOLLOWS
- A PRIMARY ADSORBER SHALL BE REPLACED WITH EITHER FRESH ADSORBENT OR THE SECONDARY ADSORBER WILL REPLACE THE PRIMARY ADSORBER AND
- B SECONDARY ADSORBER REPLACED WITH FRESH ADSORBENT
[RULE 1303 (a)-BACT]
- 7 THE ACTIVATED CARBON USED IN THE PRIMARY AND SECONDARY ADSORBER SHALL HAVE A CTC NO NOT LESS THAN 60% AS MEASURED BY ASTM METHOD D3467
[RULE 1303 (a) BACT]
- 8 SPENT CARBON REMOVED FROM THE SYSTEM SHALL BE STORED IN CLOSED CONTAINERS PRIOR TO DISPOSAL
[RULE 1303 (a)-BACT]
- 9 RECORDS SHALL BE MAINTAINED TO PROVE COMPLIANCE WITH CONDITIONS NO 4 5 AND 6 THE RECORDS SHALL BE KEPT FOR AT LEAST TWO YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1303 (a)-BACT]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

**Permit No F69293
A/N 426053**

Equipment Description

INTERNAL COMBUSTION ENGINE, VOLVO PENTA MODEL TAD120GE, DIESEL FUEL FOUR CYCLE, SIX CYLINDERS TURBOCHARGED AND AFTERCOOLED RATED AT 449 B H P DRIVING AN EMERGENCY ELECTRICAL GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a) RULE 1110 2, RULE 1470]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR WHICH INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING PURPOSES
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

[RULE 1470]

- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS
- A EMERGENCY USE HOURS OF OPERATION
 - B MAINTENANCE AND TESTING HOURS
 - C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)
- IN ADDITION, EACH TIME THE ENGINE IS STARTED MANUALLY, THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
- [RULE 1304 (a) RULE 1110 2 RULE 1470]
- 8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431 2 AND 1470
- [RULE 431 2 RULE 1470]

Emissions And Requirements

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS
 - PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F74244
A/N 438542

Equipment Description

PRESSURE WASHER, HOTSY CORPORATION MODEL NO 505C SERIAL NO C74783, DIESEL FUEL
RATED AT 197 000 BTU PER HOUR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1303 (b)(2) OFFSETS]
- 4 THIS EQUIPMENT SHALL NOT BE OPERATED MORE THAN 510 HOURS IN ANY ONE CALENDAR MONTH
[RULE 1303 (b)(2)-OFFSETS]
- 5 RECORDS SHALL BE MAINTAINED WHENEVER THE EQUIPMENT IS OPERATED TO PROVE COMPLIANCE WITH CONDITION NO FOUR THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1303 (b)(2) OFFSETS RULE 1303 (a) BACT]

Emissions And Requirements

- 6 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
CO 2000 PPMV RULE 407
SOX 500 PPMV RULE 407
PM 0.1 GR/SCF RULE 409



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

**Permit No F69291
A/N 426055**

Equipment Description

INTERNAL COMBUSTION ENGINE DETROIT DIESEL MODEL R123 7K36 DIESEL FUEL,
TURBOCHARGED AND AFTERCOOLED RATED AT 1120 B H P DRIVING AN EMERGENCY ELECTRICAL
STAND-BY GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA
AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS
ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING
CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED
TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 4 THIS ENGINE SHALL NOT OPERATE MORE THAN 200 HOURS IN ANY ONE YEAR, WHICH
INCLUDES NO MORE THAN 50 HOURS IN ANY ONE YEAR FOR MAINTENANCE AND TESTING
PURPOSES
[RULE 1304 (a) RULE 1110 2 RULE 1470]
- 5 THE OPERATION OF THE ENGINE BEYOND THE 50 HOURS PER YEAR ALLOTTED FOR ENGINE
MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID
POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE
ELECTRICAL GRID OPERATOR OR ELECTRIC UTILITY HAS ORDERED ROTATING OUTAGES IN
THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS
TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY
SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE
TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A
ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[RULE 1304 (a) RULE 1470]
- 6 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING
INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR
REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN
REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

[RULE 1470]

- 7 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS
- A EMERGENCY USE HOURS OF OPERATION
 - B MAINTENANCE AND TESTING HOURS
 - C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)
- IN ADDITION EACH TIME THE ENGINE IS STARTED MANUALLY THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF THREE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR
- [RULE 1304 (a), RULE 1110 2 RULE 1470]
- 8 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431 2 AND 1470
- [RULE 431 2 RULE 1470]

Equipment Description



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F84370
A/N 453517

Equipment Description

PRESSURE WASHER LANDA MODEL NO MVC4 3500E, SERIAL NO 1, DIESEL FIRED FUEL RATED AT 336 000 BTU PER HOUR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1303 (b)(2) OFFSETS]
- 4 THIS EQUIPMENT SHALL NOT BE OPERATED MORE THAN 270 HOURS IN ANY ONE CALENDAR MONTH
[RULE 1303 (b)(2)-OFFSETS RULE 1401]
- 5 THIS EQUIPMENT SHALL NOT BE OPERATED MORE THAN 20 HOURS IN ANY ONE DAY
[RULE 1303 (a)]
- 6 RECORDS SHALL BE MAINTAINED WHENEVER THE EQUIPMENT IS OPERATED TO PROVE COMPLIANCE WITH CONDITION NO FOUR THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1303 (b)(2)-OFFSETS RULE 1303 (a) BACT]

Emissions And Requirements

- 7 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
 - CO 2000 PPMV RULE 407
 - SOX 500 PPMV RULE 407
 - PM 0.1 GR/SCF, RULE 409



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F84372
A/N 453518

Equipment Description

PRESSURE WASHER, LANDA MODEL NO MVC4 3500E SERIAL NO 2 DIESEL FIRED FUEL RATED AT 336,000 BTU PER HOUR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1303 (b)(2) OFFSETS]
- 4 THIS EQUIPMENT SHALL NOT BE OPERATED MORE THAN 270 HOURS IN ANY ONE CALENDAR MONTH
[RULE 1303 (b)(2)-OFFSETS RULE 1401]
- 5 THIS EQUIPMENT SHALL NOT BE OPERATED MORE THAN 20 HOURS IN ANY ONE DAY
[RULE 1303 (a)]
- 6 RECORDS SHALL BE MAINTAINED WHENEVER THIS EQUIPMENT IS OPERATED TO PROVE COMPLIANCE WITH CONDITION NO FOUR THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1303 (b)(2) OFFSETS RULE 1303 (a)-BACT]

Emissions And Requirements

- 7 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
 - CO 2000 PPMV RULE 407
 - SOX 500 PPMV RULE 407
 - PM 0.1 GR/SCF RULE 409



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F74347
A/N 438540

Equipment Description

PRESSURE WASHER, LANDA MODEL NO PGHW5 3000E SERIAL NO P0604-83535 DIESEL FIRED FUEL
RATED AT 469 754 BTU PER HOUR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA
AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS
ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING
CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO
INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1303 (b)(2)-OFFSETS]
- 4 THIS EQUIPMENT SHALL NOT BE OPERATED MORE THAN 210 HOURS IN ANY ONE CALENDAR
MONTH
[RULE 1303 (b)(2) OFFSETS]
- 5 RECORDS SHALL BE MAINTAINED WHENEVER THIS EQUIPMENT IS OPERATED TO PROVE
COMPLIANCE WITH CONDITION NO FOUR THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE
YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1303 (b)(2) OFFSETS]

Emissions And Requirements

- 6 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES
AND REGULATIONS
CO 2000 PPMV RULE 407
SOX 500 PPMV RULE 407
PM 0.1 GR/SCF RULE 409



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F84369
A/N 456387

Equipment Description

PRESSURE WASHER LANDA MODEL NO MHP4 35224E DIESEL FIRED FUEL RATED AT 330 000 BTU PER HOUR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1303 (b)(2) OFFSETS]
- 4 THIS EQUIPMENT SHALL NOT BE OPERATED MORE THAN 300 HOURS IN ANY ONE CALENDAR MONTH
[RULE 1303 (b)(2)-OFFSETS RULE 1401]
- 5 THIS EQUIPMENT SHALL NOT BE OPERATED MORE THAN 20 HOURS IN ANY ONE DAY
[RULE 1303 (a)]
- 6 RECORDS SHALL BE MAINTAINED WHENEVER THE EQUIPMENT IS OPERATED TO PROVE COMPLIANCE WITH CONDITION NO FOUR THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1303 (b)(2)-OFFSETS RULE 1303 (a)-BACT]

Emissions And Requirements

- 7 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
 - CO 2000 PPMV RULE 407
 - SOX 500 PPMV RULE 407
 - PM 0.1 GR/SCF RULE 409



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F95054
A/N 474757

Equipment Description

PRESSURE WASHER, WAYNE COMBUSTION MODEL NO EHA, DIESEL FIRED FUEL RATED AT 454 000 BTU PER HOUR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1303 (b)(2)-OFFSETS]
- 4 THIS EQUIPMENT SHALL NOT BE OPERATED MORE THAN 210 HOURS IN ANY ONE CALENDAR MONTH
[RULE 1303 (b)(2)-OFFSETS RULE 1401]
- 5 THIS EQUIPMENT SHALL NOT BE OPERATED MORE THAN 14 HOURS IN ANY ONE DAY
[RULE 1303 (a)]
- 6 RECORDS SHALL BE MAINTAINED WHENEVER THE EQUIPMENT IS OPERATED TO PROVE COMPLIANCE WITH CONDITION NO FOUR AND FIVE THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1303 (b)(2) OFFSETS RULE 1303 (a) BACT]

Emissions And Requirements

- 7 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
CO 2000 PPMV RULE 407
SOX 500 PPMV RULE 407
PM 0.1 GR/SCF RULE 409



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F96189
A/N 476431

Equipment Description

PRESSURE WASHER, ALLIED MANUFACTURING MODEL NO E3000 5GT, DIESEL FIRED FUEL, RATED AT 454,000 BTU PER HOUR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1303 (b)(2)-OFFSETS]
- 4 THIS EQUIPMENT SHALL NOT BE OPERATED MORE THAN 210 HOURS IN ANY ONE CALENDAR MONTH
[RULE 1303 (b)(2)-OFFSETS RULE 1401]
- 5 THIS EQUIPMENT SHALL NOT BE OPERATED MORE THAN 14 HOURS IN ANY ONE DAY
[RULE 1303 (a)]
- 6 RECORDS SHALL BE MAINTAINED WHENEVER THE EQUIPMENT IS OPERATED TO PROVE COMPLIANCE WITH CONDITION NO FOUR AND FIVE THE RECORDS SHALL BE KEPT FOR AT LEAST FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1303 (b)(2)-OFFSETS RULE 1303 (a)-BACT]

Emissions And Requirements

- 7 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
CO 2000 PPMV RULE 407
SOX 500 PPMV RULE 407
PM 0.1 GR/SCF, RULE 409



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

**Permit No F40651
A/N 381314**

Equipment Description

FILM CLEANING MACHINE LIPSNER SMITH MODEL CF3000 MARK 6 SERIAL NO H9216 3-8 W X 2-7' D X 6 5' H , ELECTRICALLY HEATED WITH A REFRIGERATED CONDENSER 14 KW

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 THIS EQUIPMENT SHALL ONLY USE HFE 8200 AS THE CLEANING SOLVENT
[RULE 1303 (a)-BACT]
- 4 MATERIAL SAFETY DATA SHEETS FOR THE CLEANING SOLVENT SHALL BE KEPT CURRENT AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1303 (a)-BACT]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F97489
A/N 480452

Equipment Description

PRESSURE WASHER, ALLIED MANUFACTURING MODEL NO E3000-5GT DIESEL FIRED FUEL RATED
AT 454 000 BTU PER HOUR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA
AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS
ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING
CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO
INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1303 (b)(2) OFFSETS]
- 4 THIS EQUIPMENT SHALL NOT BE OPERATED MORE THAN 210 HOURS IN ANY ONE CALENDAR
MONTH
[RULE 1303 (b)(2) OFFSETS RULE 1401]
- 5 THIS EQUIPMENT SHALL NOT BE OPERATED MORE THAN 14 HOURS IN ANY ONE DAY
[RULE 1303 (a)]
- 6 RECORDS SHALL BE MAINTAINED WHENEVER THE EQUIPMENT IS OPERATED TO PROVE
COMPLIANCE WITH CONDITION NO FOUR AND FIVE THE RECORDS SHALL BE KEPT FOR AT
LEAST FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1303 (b)(2) OFFSETS RULE 1303 (a)-BACT]

Emissions And Requirements

- 7 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES
AND REGULATIONS
CO 2000 PPMV RULE 407
SOX 500 PPMV, RULE 407
PM 0.1 GR/SCF RULE 409



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No F97490
A/N 480453

Equipment Description

PRESSURE WASHER ALLIED MANUFACTURING MODEL NO E3000-5GT DIESEL FIRED FUEL, RATED
AT 454 000 BTU PER HOUR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA
AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS
ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING
CONDITION AT ALL TIMES
[RULE 204]
- 3 AN OPERATIONAL NON RESETTABLE TIME METER SHALL BE INSTALLED AND MAINTAINED TO
INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1303 (b)(2)-OFFSETS]
- 4 THIS EQUIPMENT SHALL NOT BE OPERATED MORE THAN 210 HOURS IN ANY ONE CALENDAR
MONTH
[RULE 1303 (b)(2) OFFSETS RULE 1401]
- 5 THIS EQUIPMENT SHALL NOT BE OPERATED MORE THAN 14 HOURS IN ANY ONE DAY
[RULE 1303 (a)]
- 6 RECORDS SHALL BE MAINTAINED WHENEVER THE EQUIPMENT IS OPERATED TO PROVE
COMPLIANCE WITH CONDITION NO FOUR AND FIVE THE RECORDS SHALL BE KEPT FOR AT
LEAST FIVE YEARS AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST
[RULE 1303 (b)(2) OFFSETS RULE 1303 (a) BACT]

Emissions And Requirements

- 7 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES
AND REGULATIONS
CO 2000 PPMV RULE 407
SOX 500 PPMV RULE 407
PM 0.1 GR/SCF RULE 409



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

**Permit No F97491
A/N 481202**

Equipment Description

INTERNAL COMBUSTION ENGINE, CATERPILLAR, MODEL 3516C-DITA DIESEL FUEL, TURBOCHARGED AND AFTERCOOLED RATED AT 2397 B H P DRIVING AN EMERGENCY ELECTRICAL GENERATOR

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 THE OPERATOR SHALL COMPLY WITH ALL APPLICABLE REQUIREMENTS OF RULES 431 2, RULE 1470 AND 1472
[RULE 431 2 RULE 1470 RULE 1472]
- 4 AN OPERATIONAL NON RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME
[RULE 1110 2 RULE 1303 (b)(2)-OFFSETS RULE 1470]
- 5 THIS ENGINE SHALL BE OPERATED TO A MAXIMUM OF 200 HOURS PER CALENDAR YEAR AND SHALL BE OPERATED TO A MAXIMUM OF 50 HOURS PER YEAR FOR REGULAR MAINTENANCE AND TESTING
[RULE 1110 2 RULE 1303 (b)(2) BACT, RULE 1470]
- 6 OPERATION BEYOND 50 HOURS PER YEAR FOR REGULAR MAINTENANCE AND TESTING FOR THIS ENGINE SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT
[Rule 1303 (a)(1)-BACT Rule 1470]
- 7 THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO SO BY THE UTILITY OR THE GRID OPERATOR

[Rule 1303 (a)(1) BACT Rule 1470]

- 8 AN ENGINE OPERATING LOG SHALL BE MAINTAINED WHICH ON A MONTHLY BASIS SHALL INCLUDE MANUAL AND AUTOMATIC OPERATION AND SHALL LIST ALL ENGINE OPERATIONS IN EACH OF THE FOLLOWING AREAS

A EMERGENCY USE HOURS OF OPERATION

B MAINTENANCE AND TESTING HOURS

C OTHER OPERATING HOURS (DESCRIBE THE REASON FOR OPERATION)

IN ADDITION EACH TIME THE ENGINE IS STATED MANUALLY THE LOG SHALL INCLUDE THE DATE OF OPERATION AND THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION THE LOG SHALL BE KEPT FOR A MINIMUM OF FIVE CALENDAR YEARS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST THE TOTAL HOURS OF OPERATION FOR THE PREVIOUS CALENDAR YEAR SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR

[RULE 1303 (b)(2) offsets Rule 1470]

Emissions And Requirements

- 9 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS

PM RULE 404 SEE APPENDIX B FOR EMISSION LIMITS

PM RULE 1470



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

Permit No N24131
A/N 480450

Equipment Description

Fuel Storage and Dispensing Facility Consisting of

- 1) 8 - GASOLINE BELLOWS-LESS NOZZLES DISPENSING 8 PRODUCTS EQUIPPED WITH PHASE II VAPOR RECOVERY SYSTEM HEALY PHASE II EVR NOT INCLUDING ISD (VR 201 F)
- 2) 2 - GASOLINE UNDERGROUND STORAGE TANKS EACH 20 000 GALLON CAPACITY, EQUIPPED WITH PHASE I VAPOR RECOVERY SYSTEM OPW (VR-102-A/H) 2 METHANOL COMPATIBLE

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT WAS ISSUED, UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
[RULE 204]
- 3 EXCEPT FOR DIESEL TRANSFERS PHASE I VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO STORAGE TANKS
[RULE 461]
- 4 EXCEPT FOR DIESEL TRANSFERS PHASE II VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO MOTOR VEHICLES AS DEFINED IN RULE 461
[RULE 461]
- 5 ALL PHASE I AND PHASE II VAPOR RECOVERY EQUIPMENT AT THIS FACILITY SHALL BE INSTALLED OPERATED AND MAINTAINED TO MEET ALL CALIFORNIA AIR RESOURCES BOARD CERTIFICATION REQUIREMENTS
[RULE 461]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 6 NEW EQUIPMENT INSTALLATIONS AND SUBSEQUENT SERVICE AND REPAIRS FOR ANY CERTIFIED COMPONENT FOR WHICH THIS PERMIT WAS ISSUED SHALL ONLY BE PERFORMED BY A CURRENT AND CERTIFIED PERSON WHO HAS SUCCESSFULLY COMPLETED THE MANUFACTURER S TRAINING COURSE AND APPROPRIATE INTERNATIONAL CODE COUNCIL (ICC) CERTIFICATION COMPLETION OF ANY AQMD TRAINING COURSE DOES NOT CONSTITUTE AS A SUBSTITUTE FOR THIS REQUIREMENT PROOF OF SUCCESSFUL COMPLETION OF ANY MANUFACTURER TRAINING COURSE SHALL BE WITH THE MANUFACTURER
[RULE 461]
- 7 DEPENDING ON THE SYSTEM CONFIGURATION A LEAK RATE TEST OF DROP TUBE/DRAIN VALVE ASSEMBLY SHALL BE CONDUCTED TO QUANTIFY THE PRESSURE INTEGRITY OF BOTH THE DROP TUBE AND DRAIN VALVE SEAL OR A LEAK RATE TEST OF DROP TUBE OVERFILL PREVENTION DEVICE AND DRAIN VALVE SHALL BE CONDUCTED TO QUANTIFY THE PRESSURE INTEGRITY OF THE DROP TUBE OVERFILL PREVENTION DEVICE AND THE PRESSURE INTEGRITY OF THE SPILL CONTAINER DRAIN VALVE EITHER TEST SHALL BE CONDUCTED AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH TEST PROCEDURE METHOD TP 201 1C (OCTOBER 8, 2003) OR TP 201 1D (OCTOBER 8 2003) RESPECTIVELY RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY TWO (72) HOURS OF TEST
[RULE 461]
- 8 A LEAK RATE AND CRACKING PRESSURE TEST OF PRESSURE/VACUUM RELIEF VENT VALVES SHALL BE CONDUCTED AT LEAST ONCE EVERY THREE (3) YEARS THEREAFTER TO DETERMINE THE PRESSURE AND VACUUM AT WHICH THE PRESSURE/VACUUM VENT VALVE ACTUATES AND TO DETERMINE THE VOLUMETRIC LEAK RATE AT A GIVEN PRESSURE THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH THE TEST PROCEDURE METHOD TP 201 1E (OCTOBER 8 2003) RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY TWO (72) HOURS OF TEST THIS TEST RESULT SHALL BE KEPT ON SITE FOR THREE (3) YEARS AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST
[RULE 461]
- 9 A STATIC TORQUE TEST OF ROTATABLE PHASE I ADAPTORS SHALL BE CONDUCTED TO QUANTIFY THE AMOUNT OF STATIC TORQUE REQUIRED TO START THE ROTATION OF THE ROTATABLE PHASE I ADAPTORS THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH THE TEST PROCEDURE METHOD OUTLINED IN TP 201 1B (OCTOBER 8 2003) AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST RESULTS SHALL BE SUBMITTED TO THE AQMD OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY TWO (72) HOURS OF TEST
[RULE 461]
- 10 THE PHASE II VAPOR RECOVERY SYSTEM SHALL BE INSTALLED OPERATED AND MAINTAINED SUCH THAT THE MAXIMUM ALLOWABLE PRESSURE THROUGH THE RISER AND UNDERGROUND PIPING DOES NOT EXCEED THE DYNAMIC BACK PRESSURE DESCRIBED BY THE CALIFORNIA AIR RESOURCES BOARD EXECUTIVE ORDER BY WHICH THE SYSTEM WAS CERTIFIED

NITROGEN FLOWRATES

DYNAMIC BACK PRESSURE



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

(CFH)
60

(INCHES OF WATER)
0.50

DYNAMIC BACK PRESSURE TESTS SHALL BE CONDUCTED TO DETERMINE THE PHASE II SYSTEM VAPOR RECOVERY BACK PRESSURES. THE TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE TP 201.4, METHODOLOGY 4 AND 6 (JULY 3, 2002), AS A PERFORMANCE TEST. THIS TEST SHALL BE A ONE-TIME TEST AND THE RESULTS KEPT PERMANENTLY ON SITE. RESULTS SHALL BE SUBMITTED TO THE AQMD OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY TWO (72) HOURS OF TESTS [RULE 461]

- 11 A STATIC PRESSURE LEAK DECAY TEST SHALL BE CONDUCTED TO DEMONSTRATE THAT THE STORAGE TANKS, THE REMOTE AND/OR NOZZLE VAPOR RECOVERY CHECK VALVES, ASSOCIATED VAPOR RETURN PIPING AND FITTINGS ARE FREE FROM VAPOR LEAKS. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE METHOD TP-201.3 (MARCH 17, 1999) AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST [RULE 461]
- 12 A STATIC PRESSURE PERFORMANCE TEST FOR THE HEALY CLEAN AIR SEPARATOR USING BOTH THE VACUUM DECAY PROCEDURE AND THE POSITIVE PRESSURE PROCEDURE SHALL BE CONDUCTED TO QUANTIFY THE VAPOR TIGHTNESS OF THE TANK PRESSURE MANAGEMENT SYSTEM. THESE TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH EXHIBIT 4 OF CARB EXECUTIVE ORDER VR-201 F AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY TWO (72) HOURS OF TEST [RULE 461]
- 13 A VAPOR TO LIQUID VOLUME RATIO TEST SHALL BE CONDUCTED TO QUANTIFY THE VAPOR TO LIQUID (V/L) VOLUMETRIC RATIO OF THE HEALY CLEAN AIR SEPARATOR SYSTEM. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH EXHIBIT 5 OF CARB EXECUTIVE ORDER VR 201 F AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST [RULE 461]
- 14 A NOZZLE BAG TEST SHALL BE CONDUCTED ON THE HEALY PHASE II EVR NOZZLES TO VERIFY THE INTEGRITY OF THE VAPOR VALVE. THE TEST SHALL BE CONDUCTED ON ANY NEWLY INSTALLED OR REPLACED HEALY PHASE II EVR NOZZLES AND IN ACCORDANCE WITH EXHIBIT 7 OF CARB EXECUTIVE ORDER VR-201 F. RESULTS SHALL BE SUBMITTED TO THE AQMD OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY TWO (72) HOURS OF TEST [RULE 461]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 15 THE STATIC PRESSURE LEAK DECAY TEST TP 201.3 SHALL BE CONDUCTED IN ACCORDANCE WITH EXHIBIT 8 OF CARB EXECUTIVE ORDER VR-202 F. VERIFICATION OF COMPLETING EACH STEP AS OUTLINED SHALL BE DOCUMENTED BY SUBMITTING A COPY OF EXHIBIT 8 TO THE AQMD OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST
[RULE 461]
- 16 A CARB CERTIFIED PHASE II ENHANCED VAPOR RECOVERY SYSTEM SHALL BE FULLY PERMITTED, INSTALLED, AND TESTED BY OCTOBER 1, 2008. FAILURE TO ACHIEVE THIS CONDITION BY OCTOBER 1, 2008 SHALL RESULT IN THE OWNER/OPERATOR TO FILE A DISTRICT APPROVED COMPLIANCE PLAN OUTLINING THE INCREMENTS OF PROGRESS TOWARDS COMPLETING THE INSTALLATION OF A CARB CERTIFIED PHASE II ENHANCED VAPOR RECOVERY SYSTEM BY APRIL 1, 2009
[RULE 461]
- 17 IF THE OWNER/OPERATOR PLANS TO PERMANENTLY CEASE ALL GASOLINE DISPENSING OPERATIONS BEFORE APRIL 1, 2009, A COMPLIANCE PLAN SHALL BE FILED DECLARING TO IRREVOCABLY SURRENDER THEIR PERMIT TO OPERATE
[RULE 461]
- 18 THE AQMD SHALL BE NOTIFIED BY E-MAIL AT R461TESTING@AQMD.GOV OR BY FACSIMILE AT TELEPHONE NUMBER (909) 396 3606 AT LEAST SEVENTY TWO (72) HOURS PRIOR TO ANY OF THE ABOVE MENTIONED TESTING REQUIREMENTS. SUCH NOTIFICATION SHALL INCLUDE THE NAME OF THE OWNER OR OPERATOR, THE NAME OF THE CONTRACTOR, THE LOCATION OF THE FACILITY, AND THE SCHEDULED START AND COMPLETION DATES OF THE TESTS TO BE PERFORMED
[RULE 461]
- 19 THE TESTING FOR THE ABOVE MENTIONED TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH THE MOST RECENT RULE 461 AMENDMENT OR CARB EXECUTIVE ORDER REQUIREMENTS, WHICHEVER IS MORE STRINGENT
[RULE 461]
- 20 ALL RECORDS AND TEST RESULTS THAT ARE REQUIRED TO BE MAINTAINED BY RULE 461 SHALL BE KEPT ON SITE FOR FIVE YEARS AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST
[RULE 461]
- 21 SHOULD THE FACILITY DISPENSE MORE THAN 600,000 GALLONS OF GASOLINE PER CALENDAR YEAR AND IF THE FACILITY UNDERGOES A MAJOR MODIFICATION AS DEFINED BY CARB'S ADVISORY LETTER NUMBER 336, 'ENHANCED VAPOR RECOVERY IMPLEMENTATION UPDATE' DATED APRIL 15, 2005, THE OPERATOR SHALL IMMEDIATELY CEASE ALL GASOLINE DISPENSING OPERATIONS AND FILE AN APPLICATION FOR A NEW PERMIT TO CONSTRUCT/OPERATE TO INSTALL A CARB CERTIFIED ISD SYSTEM. GASOLINE DISPENSING OPERATIONS SHALL NOT RESUME UNTIL THE ISD SYSTEM HAS BEEN GRANTED A PERMIT TO CONSTRUCT/OPERATE AND HAS BEEN FULLY INSTALLED, TESTED, AND OPERATIVE
[RULE 461]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 22 SHOULD THE FACILITY DISPENSE MORE THAN 600 000 GALLONS OF GASOLINE IN ANY CALENDAR YEAR AND IF THE FACILITY DOES NOT UNDERGO A MAJOR MODIFICATION AS DEFINED BY CARB S ADVISORY LETTER NUMBER 336 'ENHANCED VAPOR RECOVERY IMPLEMENTATION UPDATE' DATED APRIL 15, 2005 THE OPERATOR SHALL FILE AN APPLICATION FOR A NEW PERMIT TO CONSTRUCT/OPERATE TO INSTALL A CARB CERTIFIED ISD SYSTEM THE ISD SYSTEM SHALL BE FULLY INSTALLED, TESTED AND OPERATIVE BASED ON THE FOLLOWING TABLE

<u>GASOLINE THROUGHPUT PER CALENDAR YEAR</u>	<u>DATE</u>
GREATER THAN 1 8 MILLION GALLONS	SEPTEMBER 1 2009
BETWEEN 600 000 AND 1 8 MILLION GALLONS	SEPTEMBER 1 2010

[RULE 461]

Periodic Monitoring

- 23 THE OPERATOR SHALL HAVE A PERSON THAT HAS BEEN TRAINED IN ACCORDANCE WITH RULE 461(d)(5) CONDUCT A SEMI ANNUAL INSPECTION OF THE GASOLINE TRANSFER AND DISPENSING EQUIPMENT THE FIRST INSPECTION SHALL BE IN ACCORDANCE WITH RULE 461 ATTACHMENT B, THE SECOND INSPECTION SHALL BE IN ACCORDANCE WITH RULE 461, ATTACHMENT C AND THE SUBSEQUENT INSPECTIONS SHALL ALTERNATE PROTOCOLS THE OPERATOR SHALL KEEP RECORDS OF THE INSPECTION AND THE REPAIRS IN ACCORDANCE TO RULE 461 AND SECTION K OF THIS PERMIT
- [RULE 3004 (a)(4)]

Emissions And Requirements

- 24 THIS EQUIPMENT IS SUBJECT TO THE APPLICABLE REQUIREMENTS OF THE FOLLOWING RULES AND REGULATIONS
- VOC RULE 461
VOC RULE 1170



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

PERMIT TO OPERATE

**Permit No N24132
A/N 480951**

Equipment Description

Fuel Storage and Dispensing Facility Consisting of

- 1) 2 - GASOLINE BELLOWS LESS NOZZLES DISPENSING 2 PRODUCTS EQUIPPED WITH PHASE II VAPOR RECOVERY SYSTEM HEALY PHASE II EVR NOT INCLUDING ISD (VR 201 F)
- 2) 1 - GASOLINE UNDERGROUND STORAGE TANK, 10 000 GALLON CAPACITY EQUIPPED WITH PHASE I VAPOR RECOVERY SYSTEM OPW (VR-102 E/H) 1 METHANOL COMPATIBLE

Conditions

- 1 OPERATION OF THIS EQUIPMENT SHALL BE IN COMPLIANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT WAS ISSUED UNLESS OTHERWISE NOTED BELOW
[RULE 204]
- 2 THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES
RULE 204]
- 3 EXCEPT FOR DIESEL TRANSFERS PHASE I VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO STORAGE TANKS
RULE 461]
- 4 EXCEPT FOR DIESEL TRANSFERS PHASE II VAPOR RECOVERY SYSTEMS SHALL BE IN FULL OPERATION WHENEVER FUEL IS BEING TRANSFERRED INTO MOTOR VEHICLES AS DEFINED IN
RULE 461
RULE 461]
- 5 ALL PHASE I AND PHASE II VAPOR RECOVERY EQUIPMENT AT THIS FACILITY SHALL BE INSTALLED OPERATED AND MAINTAINED TO MEET ALL CALIFORNIA AIR RESOURCES BOARD CERTIFICATION REQUIREMENTS
RULE 461]



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

- 6 NEW EQUIPMENT INSTALLATIONS AND SUBSEQUENT SERVICE AND REPAIRS FOR ANY CERTIFIED COMPONENT FOR WHICH THIS PERMIT WAS ISSUED SHALL ONLY BE PERFORMED BY A CURRENT AND CERTIFIED PERSON WHO HAS SUCCESSFULLY COMPLETED THE MANUFACTURER'S TRAINING COURSE AND APPROPRIATE INTERNATIONAL CODE COUNCIL (ICC) CERTIFICATION COMPLETION OF ANY AQMD TRAINING COURSE DOES NOT CONSTITUTE AS A SUBSTITUTE FOR THIS REQUIREMENT PROOF OF SUCCESSFUL COMPLETION OF ANY MANUFACTURER TRAINING COURSE SHALL BE WITH THE MANUFACTURER
RULE 461]
- 7 DEPENDING ON THE SYSTEM CONFIGURATION A LEAK RATE TEST OF DROP TUBE/DRAIN VALVE ASSEMBLY SHALL BE CONDUCTED TO QUANTIFY THE PRESSURE INTEGRITY OF BOTH THE DROP TUBE AND DRAIN VALVE SEAL OR A LEAK RATE TEST OF DROP TUBE OVERFILL PREVENTION DEVICE AND DRAIN VALVE SHALL BE CONDUCTED TO QUANTIFY THE PRESSURE INTEGRITY OF THE DROP TUBE OVERFILL PREVENTION DEVICE AND THE PRESSURE INTEGRITY OF THE SPILL CONTAINER DRAIN VALVE EITHER TEST SHALL BE CONDUCTED AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH TEST PROCEDURE METHOD TP 201 1C (OCTOBER 8 2003) OR TP 201 1D (OCTOBER 8 2003), RESPECTIVELY RESULTS SHALL BE SUBMITTED TO THE AQMD OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST
RULE 461]
- 8 A LEAK RATE AND CRACKING PRESSURE TEST OF PRESSURE/VACUUM RELIEF VENT VALVES SHALL BE CONDUCTED AT LEAST ONCE EVERY THREE (3) YEARS THEREAFTER TO DETERMINE THE PRESSURE AND VACUUM AT WHICH THE PRESSURE/VACUUM VENT VALVE ACTUATES AND TO DETERMINE THE VOLUMETRIC LEAK RATE AT A GIVEN PRESSURE THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH THE TEST PROCEDURE METHOD TP-201 1E (OCTOBER 8 2003) RESULTS SHALL BE SUBMITTED TO THE AQMD OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY TWO (72) HOURS OF TEST THIS TEST RESULT SHALL BE KEPT ON SITE FOR THREE (3) YEARS AND MADE AVAILABLE TO DISTRICT REPRESENTATIVES UPON REQUEST
RULE 461]
- 9 A STATIC TORQUE TEST OF ROTATABLE PHASE I ADAPTORS SHALL BE CONDUCTED TO QUANTIFY THE AMOUNT OF STATIC TORQUE REQUIRED TO START THE ROTATION OF THE ROTATABLE PHASE I ADAPTORS THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH THE TEST PROCEDURE METHOD OUTLINED IN TP 201 1B (OCTOBER 8 2003) AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST RESULTS SHALL BE SUBMITTED TO THE AQMD OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY TWO (72) HOURS OF TEST
RULE 461]
- 10 THE PHASE II VAPOR RECOVERY SYSTEM SHALL BE INSTALLED OPERATED AND MAINTAINED SUCH THAT THE MAXIMUM ALLOWABLE PRESSURE THROUGH THE RISER AND UNDERGROUND PIPING DOES NOT EXCEED THE DYNAMIC BACK PRESSURE DESCRIBED BY THE CALIFORNIA AIR RESOURCES BOARD EXECUTIVE ORDER BY WHICH THE SYSTEM WAS CERTIFIED



FACILITY PERMIT TO OPERATE UNIVERSAL CITY STUDIOS, LLC

NITROGEN FLOWRATES
(CFH)
60

DYNAMIC BACK PRESSURE
(INCHES OF WATER)
0.50

DYNAMIC BACK PRESSURE TESTS SHALL BE CONDUCTED TO DETERMINE THE PHASE II SYSTEM VAPOR RECOVERY BACK PRESSURES. THE TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE TP 201.4 METHODOLOGY 4 AND 6 (JULY 3 2002) AS A PERFORMANCE TEST. THIS TEST SHALL BE A ONE-TIME TEST AND THE RESULTS KEPT PERMANENTLY ON SITE. RESULTS SHALL BE SUBMITTED TO THE AQMD OFFICE OF ENGINEERING AND COMPLIANCE, WITHIN SEVENTY-TWO (72) HOURS OF TESTS. RULE 461]

- 11 A STATIC PRESSURE LEAK DECAY TEST SHALL BE CONDUCTED TO DEMONSTRATE THAT THE STORAGE TANKS, THE REMOTE AND/OR NOZZLE VAPOR RECOVERY CHECK VALVES ASSOCIATED VAPOR RETURN PIPING AND FITTINGS ARE FREE FROM VAPOR LEAKS. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH CARB TEST PROCEDURE METHOD TP 201.3 (MARCH 17 1999) AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD, OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST. RULE 461]
- 12 A STATIC PRESSURE PERFORMANCE TEST FOR THE HEALY CLEAN AIR SEPARATOR USING BOTH THE VACUUM DECAY PROCEDURE AND THE POSITIVE PRESSURE PROCEDURE SHALL BE CONDUCTED TO QUANTIFY THE VAPOR TIGHTNESS OF THE TANK PRESSURE MANAGEMENT SYSTEM. THESE TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH EXHIBIT 4 OF CARB EXECUTIVE ORDER VR-201 F AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST. RULE 461]
- 13 A VAPOR TO LIQUID VOLUME RATIO TEST SHALL BE CONDUCTED TO QUANTIFY THE VAPOR TO LIQUID (V/L) VOLUMETRIC RATIO OF THE HEALY CLEAN AIR SEPARATOR SYSTEM. THE TEST SHALL BE CONDUCTED IN ACCORDANCE WITH EXHIBIT 5 OF CARB EXECUTIVE ORDER VR 201 F AS A PERFORMANCE TEST AND AS A REVERIFICATION TEST. RESULTS SHALL BE SUBMITTED TO THE AQMD OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST. RULE 461]
- 14 A NOZZLE BAG TEST SHALL BE CONDUCTED ON THE HEALY PHASE II EVR NOZZLES TO VERIFY THE INTEGRITY OF THE VAPOR VALVE. THE TEST SHALL BE CONDUCTED ON ANY NEWLY INSTALLED OR REPLACED HEALY PHASE II EVR NOZZLES AND IN ACCORDANCE WITH EXHIBIT 7 OF CARB EXECUTIVE ORDER VR 201 F. RESULTS SHALL BE SUBMITTED TO THE AQMD OFFICE OF ENGINEERING AND COMPLIANCE WITHIN SEVENTY-TWO (72) HOURS OF TEST. RULE 461]